

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	993	972	956	946	981	965	972	941	985	947	938	981	938	976	950	950	968	955	976	981	988	983	978	967	
	2号炉	979	1002	982	976	998	1018	994	958	877					991	980	1001	978	971	951	965	964	979	969	967	8:32～13:00給じん停止
2	1号炉	982	988	954	961	950	977	954	956	950	958	983	995	942	945	980	977	971	957	942	951	949	925	934	936	
	2号炉	972	981	948	933	957	967	945	963	962	934	1003	979	993	978	980	988	951	966	984	987	1003	994	975	959	
3	1号炉	930	987	1017	998	1000	1000	1008	1029	1015	1030	1024	996	999	997	1000	984	977	1006	982	999	1038	984	949	990	
	2号炉	987	999	957	942	977	961	985	998	997	969	983	975	978	924	985	965	964	994	973	982	973	953	949	1004	
4	1号炉	989	1011	1009	979	1000	1015	991	1008	993	1038	1031	1007	995	935	972	975	980	974	976	1000	985	991	1005	1023	
	2号炉	1000	974	973	981	968	988	978	997	991	1005	991	975	979	981	990	979	982	1004	989	967	981	995	1007	1017	
5	1号炉	1023	1006	990	984	981	970	956	968	966	989	987	1012	980	981	983	988	982	990	996	969	974	968	966	971	
	2号炉	988	959	993	990	967	996	976	1008	986	993	970	993	992	1005	1000	949	965	994	1000	975	969	963	982	968	
6	1号炉	976	952	962	919	941	958	977	967	1016	1014	991	996	990	964	996	1000	984	994	1022	990	973	981	973	949	
	2号炉	991	952	973	941	972	950	931	974	987	978	965	964	982	950	971	973	990	1001	1006	997	959	996	990	922	
7	1号炉	955	959	969	965	962	959	982	1010	915					1023	993	1015	1005	987	1003	991	1030	1039	1025	1037	8:34～13:41給じん停止
	2号炉	961	953	986	974	934	975	969	996	970	936	964	984	936	900	947	903	909	953	949	1008	1030	1037	997	1007	
8	1号炉	1025	1008	1027	1034	1021	948	958	961	941	982	925														定常運転～立下げ(10:36～)
	2号炉	994	960	1020	1015	1021	1036	964	974	870																定常運転～立下げ(8:31～) 休炉
9	1号炉																									休炉
	2号炉																									休炉
10	1号炉																									休炉
	2号炉																									休炉
11	1号炉																									休炉
	2号炉																									休炉
12	1号炉																									休炉
	2号炉																									休炉
13	1号炉																									休炉
	2号炉																									休炉
14	1号炉																									休炉
	2号炉																									休炉
15	1号炉					1022	1062	1111	1071	1069	1028	1010	1003	1000	997	995	1004	1017	991	1039	905	977	1039	1028	1010	立上げ～定常運転(4:08～)
	2号炉										946	998	1007	1006	980	977	1014	998	893		935	1007	982	972	984	立上げ～定常運転(9:18～) 17:27～19:42給じん停止

	4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	1019	1017	986	994	984	985	975	986	994	996	1008	1012	1021	988	994	1002	1044	1019	1017	1014	979	1011	1019	1023	
	2号炉	1011	1014	1028	1023	984	979	966	968	994	980	983	1006	1017	1011	1020	984	1016	999	1020	1009	1004	968	984	1007	
17	1号炉	998	997	1010	1040	1022	1018	1024	1036	1049	1019	1028	1062	991	952	972	1040	1047	1021	1013	1022	986	1065	1014	1066	
	2号炉	970	994	1056	991	1007	986	974	990	988	997	1007	1008	980	999	1015	1016	1021	1007	965	965	982	1001	962	994	
18	1号炉	1051	1016	1027	1026	1033	1030	1030	1030	1029	1032	1003	1028	1025	1031	994	1023	1012	1036	1009	1007	1048	1071	1045	1051	
	2号炉	1034	1022	1055	1033	1016	1032	1057	1049	1046	1039	1017	1004	1004	1005	1048	998	1018	984		956	982	1058	1025	1001	17:50～19:02給じん停止
19	1号炉	1044	1030	1076	1108	1073	1041	1062	1026	1053	1034	1028	1065	1039	1041	1025	1031	1032	1060	1060	1048	1062	1036	1037	1027	
	2号炉	1039	998	997	1010	1007	1021	1004	1050	1018	995	1027	1036	1015	985	1023	1056	1029	1037	1037	989	1018	1045	989	1009	
20	1号炉	1019	1047	1047	1050	1071	1029	1049	1080	1049	914	1001	1051	1049	990	965	1037	1039	1033	1055	1050	1023	1037	1053	1048	
	2号炉	1032	1069	1019	988	973	1002	1037	1000	1016	1018	1013	1003	971	1015	1002	986	1015	1012	1007	1039	1028	875		992	21:15～23:00給じん停止
21	1号炉	1053	1040	1048	1080	1011	1069	1061	1013	902																定常運転～立下げ(8:43)
	2号炉	1027	1031	1021	1047	1017	1072	1052	1021	1022	1013	1018	990	982	976	1030	1004	1000	982	1041	966	999	948	1029	969	
22	1号炉																									休炉
	2号炉	994	1011	1012	966	916	974	945	1020	1033	1006	967	938	934	926	966	962	958	989	955	965	965	1010	967		22:43～24:01給じん停止
23	1号炉																									休炉
	2号炉	979	914	958	936	969	982	971	1007	885		972	910	1001	947	980	939	985	1005	1003	1000	1001	1036	1049	1007	8:32～10:02給じん停止
24	1号炉																									休炉
	2号炉	1017	1014	997	963	1001	995	1038	1032	1039	1035	1011	1025	994	1011	1026	987	976	1020	1044	1010	1016	1012		997	21:41～23:17給じん停止
25	1号炉																									休炉
	2号炉	974	995	989	960	996	1032	1014	948	943	983	986	1019	1013	1023	1014	979	1023	984	1035	1004	1038	1005	1032	1029	
26	1号炉																									休炉
	2号炉	1054	1050	1036	1029	1005		1043	1005	987	1016	1030	1029	1035	1013	990	1009	995	1027	978	964	1014	1013	1032	992	4:30～6:00給じん停止
27	1号炉																									休炉
	2号炉	1017	984	948	966	1008	998	974	1006	1011	1008	1011	1021	1005	1003	1011	1019	1027	1016	1019	1013		1008	1018	1003	19:13～21:22給じん停止
28	1号炉																									休炉
	2号炉	1037	1023	1006	1027	987	996	994	1011	1021	1016	1002	989	989	980	986	985	980	991	1002	997	1003	998	1016	1015	
29	1号炉																									休炉
	2号炉	993	968	1025	983	1025	986	1001	1031	1011	1019	986	957	976	1024	983	1021	1035	991	1030	1034	1018	993	1041	1015	
30	1号炉																									休炉
	2号炉	1004	989		965	1028	1023	1022	1039	929			994	1044	1030	985	1035	980	993	1036	1029	990	967	1017	1015	1:57～3:27給じん停止 8:35～11:28給じん停止

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	1007	1011	1027	1011	986	1012	1021	1014	1028	1009	991	973	968	967	977	985	985	976	987	991	993	981	996	991	
2	1号炉																									休炉
	2号炉	966	1001	1039	1033	1030	1045	1041	984	967	1021	1021	989	959	981	971	1034	1004	988	1000	1011	977	972	1009	987	
3	1号炉																									休炉
	2号炉	1003	974	973	865	868	980	1010	999	988	977	962	976	1002	974	982	995	986	960	1006	989	1013	985	991	987	
4	1号炉																									休炉
	2号炉	1005	980	1009	1016	999	1015	1015	1022	1026	1001	1011	1007	997	990	1001	1016	1006	996	1012	995	1016	1004	1011	1019	
5	1号炉																									休炉
	2号炉	1017	980	987	972	1024	1018	1013	1015	1010	976	1020	1003	1012	986	989	1006	1004	1000	1022	1015	1021	1024	1025	1018	
6	1号炉																									休炉
	2号炉	1010	1005	997	1015	1035	1026	1005	1011	979	1029	1005	1021	996	991	995	991	985	1019	1014	1035	1013	981	1045	1021	
7	1号炉																									休炉
	2号炉	993	1020	1015	1016	1012	1004	1006	1024	925	890	1025	999	976	1003	1000	1028	1031	1029	1018	1026	1026	1026	1010		8:40～11:07給じん停止
8	1号炉																									休炉
	2号炉	1011	1035	1037	1017	999	1020	1036	1019	1014	1017	971	1024	999	985	999	978	994	992	1008	966	1008	971	990	1022	
9	1号炉																									休炉
	2号炉	987	1034	1003	1025	1001	1001	1013	1002	1006	997	985	1001	989	1035	985	998	1013	997	1019	1009	1019	1031	984	1030	
10	1号炉																									休炉
	2号炉	1032	899		969	989	1001	1023	1000	1018	1004	1011	1006	1019	1026	999	987	1000	982	1013	1011	1002	1021	1032	1024	1:30～3:00給じん停止
11	1号炉																									休炉
	2号炉	1019	1023	1001	1015	1002	1020	1009	1034	989	988	1009	1003	1012	1000	1003	1006	980		1024	1025	1004	982	1000	1003	16:50～18:51給じん停止
12	1号炉																									休炉
	2号炉	996	1010	1018	1023	982	984	995	1002	1008	1005	996	975	975	976	997	981	996	975	982	990	1001	976	981	998	
13	1号炉																									休炉
	2号炉	994	972	1040	1015	990	991	992	1004	990	997	993	974	953	960	968	971	968	975	970	974	972	987	976	980	
14	1号炉																									
	2号炉	978	973	1026	1004	988	1007	983	1011	1007	1005	992	994	1003	998	975	1012	1000	1013	983	1028	992	1007	994	995	
15	1号炉																		931	994	990	939	993	1013	1025	立上げ～定常運転(17:44～)
	2号炉	1009	1021	989	993	1010	1018	1032	1018	865			1008	986	973	953	960	986	1021	976	972	970	983	1018	1000	8:30～11:14給じん開始

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1066	982	938	957	989	988	1015	1024	983	937	947	956	950	946	979	971	1007	984	1002	979	988	986	996	986	
	2号炉	984	1025	947	981	978	991	996	991	965	974	999	982	984	951	973	1009	989	996	1004	1029	989	989	981	989	
17	1号炉	1006	990	1010	996	1024	976	935	958	967	1024	986	976	1019	1005	986	966	980	1002	1007	1025	969	968	1004	972	
	2号炉	996	1011	1004	1007	994	1012	966	973	992	979	1004	983	1003	980	996	988	995	989	1021	1001	994	978	942	1028	
18	1号炉	1017	1002	977	1010	982	966	1022	1013	1013	988	967	1004	991	1037	982	968	957	950	999	996	1038	1007	936	1028	
	2号炉	953	999	993	993	973	986	1008	995	988	983	969	969	969	969	957	968	975	983	974	1010	1033	990	964	971	
19	1号炉	965	961	952	1005	985	983	990	9789	972	929	978	944	984	953	972	978	1014	982	952	1003	960	1005	1018	1020	
	2号炉	984	957	977	968	991	993	954	977	985	988	974	957	991	954	984	945	989	977	976	984	991	985	1004	996	
20	1号炉	998	986	1032	1001	989	1030	993	1030	991	1029	990	978	957	934	930	962	973	970	999	958	971	976	985	984	
	2号炉	1017	1005	1002	993	1008	986	977	1006	1006	925	991	982	972	966	962	984	993	969	971	981	997	989	931	962	
21	1号炉	979	975	946	989	954	956	972	993	870			1031	957	952	953	989	992	992	1051	973	992	981	965	977	8:32～11:55給じん停止
	2号炉	1006	985	985	996	997	985	1005	1012	969	1002	997	964	955	961	990	980	994	979		960	1005	987	995	991	17:57～19:02給じん停止
22	1号炉	950	962	952	969	965	1003	955	947	998	979	969	944	956	947	958	997	982	969	1000	1013	986	968	940	961	
	2号炉	992	983	992	1005	979	994	984	985	862			1023	974	955	968	992	984	982	995	981	983	981	974	971	8:30～11:18給じん停止
23	1号炉	974	969	1036	957	1027	983	1025	978	983	1021	1030	938	960	942	959	958	982	976	979	983	976	982	1004	1012	
	2号炉	991	1017	1013	1018	1001	1011	977	1019	979	991	981	992	969	983	977	951	989	982	992	1014	1001	997	995	991	
24	1号炉	1024	1024	992	1018	1009	998	992	1016	1008	994	1028	999	1021	1018	1027	970	1017	970	988	982	972	1013	1026	1018	
	2号炉	1001	993	1007	1002	1015	978	986	990	974	1000	1030	1003	992	976	1005	1002	1001	980	1002	979	988	999	1004	1009	
25	1号炉	1019	1062	1003	1012	1025	1000	1045	1043	1009	1045	1028	1026	986	1012	1039	1057	1012	1009	1018	1014	1038	1027	1037	1017	
	2号炉	997	1025	1022	1040	1022	999	1004	999	997	995	982	999	998	1013	993	1014	1013	1006	988	998	1008	1005	984	993	
26	1号炉	996	1018	1024	1001	1041	1076	1039	990	1056	1037	1067	1030	1061	1052	1068	982	964	961	1043	1040	1073	997	1010	1001	
	2号炉	1007	1001	986	1003	1017	1003	1018	1015	1018	1010	976	967	986	1001	976	1004	965	978	958	999	1009	972	975	974	
27	1号炉	1027	1000	1053	1005	1014	1011	1011	1009	1001				992	992	976	971	984	991	984	991	983	990	970	981	8:31～12:10給じん停止
	2号炉	962	980	984	1002	1001	1003	1039	993	949	965	978	970	957	940	984	957	980	959			969	968	1011	989	17:50～20:00給じん停止
28	1号炉	997	1006	989	987	1019	1014	973	958	952	931	971	988	1050	978	904	938	1000	1007	988	984	980	968	1020	1010	
	2号炉	995	995	964	969	977	949	970	961	980	951	981	972	977	968	968	966	955	972	962	974	972	972	981	965	
29	1号炉	985	1045	1051	1033	986	996	1033	999	1000	1020	1016	1023	941	929	922	970	996	927	937	940	935	935	950	963	
	2号炉	966	900	977	950	978	988	988	977																	定常運転～立下げ(8:46)
30	1号炉	956	954	968	960	971	968	967	92	927	938	938	916	924	933	934	946	938	955	955	939	965	928	971	1012	
	2号炉																									休炉
31	1号炉	1026	972	993	988	977	960	979	976	982	989	969	974	994	969	995	1036	1052	1013	1014	1000	1034	1019	1043	1005	
	2号炉																									休炉

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1020	1014	1038	1026	1058	1006	1007	1008	935	997	1037	1009	1020	1013	1011	1045	1019	1052	1069	1041	1031	1006	1067	1000	
	2号炉																									休炉
2	1号炉	985	1004	971	996	991	1013	994	1027	1018	983	999	938	939	944	938	911	943	957	1006	1016	955	994	953	937	
	2号炉																									休炉
3	1号炉	957	945	925	949	939	951	926	949	933	924	934	909	911	904	932	911	904					1000	920	936	16:54～21:40給じん停止
	2号炉																									休炉
4	1号炉	926	919	923	942	935	944	994	1013	985	935	941	929	933	948	917	932	930	906	941	945	954	970	982	974	
	2号炉																									休炉
5	1号炉	966	948	936	939	940	951	975	991	951	970	976	944	914	988	989	936	944	953	983	974	964	982	975	961	
	2号炉																									休炉
6	1号炉	964	974	985	1002	1008	1012	1002	1011	985	995	1015	986	974	1020	991	965	979	940	926	974	984	928	984	1012	
	2号炉																									休炉
7	1号炉	964	944	992	920	956	940	977	990	973	970	956	1007	992	966	998	1040	1019	1002	954	1020	1017	1018	1042	1028	
	2号炉																									立上げ～定常運転(7:56～)
8	1号炉	1016	1004	1009	1015	979	963	961	1007	967	1032	1039	997	987	1040	1004	1019	1000	1004	995	996	1054	1063	1034	1029	
	2号炉	999	975	970	969	1025	998	977	988	985	1016	983	972	975	943	961	970	983	989	970	996	1010	987	956	963	
9	1号炉	1077	1049	1046	1012	980	1006	1026	1047	983	979	984	967	954	949	938	960	995	973	982	1001	976	1002	968	991	
	2号炉	980	1014	1021	9997	964	992	1002	998	965	934	966	959	946	956	935	985	964	956	969	968	987	960	960	945	
10	1号炉	1081	1034	1000	986	967		960	981	872			1025	952	954	930	954	944	940	945	924	940	926	993	926	4:47～6:00 8:35～11:45 給じん停止
	2号炉	956	947	963	986	985	981	964	972	957	957	988	979	962	960	967	978	963	937	961	954	965	973	972	965	
11	1号炉	938	921	934	956	950	952	932	960	994	932	998	952	992	954	959	1006	955	992	986	989	1000	99+	1021	983	
	2号炉	970	979	969	991	948	974	1003	995	937	960	984	932	965	972	958	969	959	959	947	957	954	971	958	929	
12	1号炉	1007	995	1017	986	1018	969	976	952	991	950	971	945	938	939	906	918	932	954	914	956	968	942	977	954	
	2号炉	952	923	986	948	951	957	967	967	979	953	967	956	934	949	950	960	969	961	969	949	973	951	980	984	
13	1号炉	983	967	920	976	981	952	1030	972	988	945	944	948	919	920	934	935	925	945	964	995	971	964	963	993	
	2号炉	972	948	945	952	985	945	964	989	836			975	925	950	939	959	945	965	990	983	986	955	907	963	8:30～11:23給じん停止
14	1号炉	1022	960	967	953	979	961	959	1003	992	976	991	988	982	1003	993	1049	996	1032	1002	1048	997	990	1002	1018	
	2号炉	944	909	940	937	948	946	960	950	985	982	948	967	947	987	965	998	918	957	962	996	977	958	981	969	
15	1号炉	988	970	1048	1017	1005	1032	1030	984	970	997	1000	1009	1023	999	1018	1037	1007	1023	982	1012	1022	1025	1035	1042	
	2号炉	989	971	976	972	973	971	945	949	954	947	947	980	991	954	976	962	930	982	952	935	958	946	974	958	

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1020	1026	1038	996	1040	1048	1005	1011	949	992	1008	1013	937	929	944	957	954	947	948	975	995	1030	1001	1020	
	2号炉	965	969	920	958	948	955	960	948	944	943	939	940	926	904	925	944	940	923	930	937	976	941	933	956	
17	1号炉	1004	1033	1007	1012	970	1042	1059	1067	927	808	1005	1058	1008	974	974	974	1005	964	1005	1016	993	1018	1014	1016	
	2号炉	960	932	978	930	938	937	949	975	941	923	937	944	926	910	931	932	940	935	917	963	938	928	966	951	
18	1号炉	977	996	1010	993	1039	1023	1034	1040	1014	1009	1014	1003	996	1013	1044	1004	989	1028	1068	1049	1036	1032	1023	1032	
	2号炉	935	950	960	945	949	927	967	977	953	926	978	943	933	958	944	970	946	939	931	942	972	945	949	936	
19	1号炉	1046	1048	1065	1051	1041	1048	981	1001	1035	1004	981	1061	991	999	986	1015	1031	992	985	981	1033	999	1083	1004	
	2号炉	947	946	959	958	970	964	913	948	952	963	960	967	920	913	934	947	947	922	940	945	943	917	942	924	
20	1号炉	984	1024	994	1026	1003	1024	1063	995	1035	1022	974	992	1009	973	989	1025	1027	1024	1051	1065	1055	1022	1060	1052	
	2号炉	896	860	908	965	944	913	927	932	809				910	939	928	958	951	952	971	898	939	934	921	947	8:33～12:08給じん停止
21	1号炉	1044	1061	1028	1045	1060	1081	1064	1087	1062	1008	995	1011	1003	1081	1050	1074	1027	1072	1091	1039	1070	1054	1028	1046	
	2号炉	943	929	967	924	958	980	980	935	939	935	945	936	927	941	932	970	973	974	955	970	977	969	955	954	
22	1号炉	1053	1049	1041	1085	1059	1050	1009	1067	1053	1064	1045	1044	1037	1040	1057	1075	1034	1069	1011	1006	996	1018	1029	1037	
	2号炉	926	955	971	967	930	936	931	940	948	938	947	961	963	929	945	962	960	940	944	946	950	953	967	953	
23	1号炉	1029	1013	1072	1072	1018	1017	1006	1020	964	983	999	1005	955	949	990	934	942	970	963	980	1005	978	994	1005	
	2号炉	957	970	982	996	937	938	945	929	944	951	963	962	916	945	951	927	930	927	925	944	932	919	932	936	
24	1号炉	955		962	1023	1018	986	992	860	897				955	974	969	984	982	955	958	961	971	971	974	970	0:57～2:06 8:32～12:15 給じん停止
	2号炉	948	931	926	934	928	959	922	966	958	940	959	969	961	936	952	930	963	961	935	934	969	958	957	964	
25	1号炉	978	956	941	968	957	961	953	1002	1001	980	953	978	983	971	975	994	920	978	960	955	998	982	983	990	
	2号炉	953	944	957	944	953	958	957	977	955	952	943	963	966	985	970	951	972	952	952	959	978	991	956	927	
26	1号炉	960	967	992	978	981	990	1007	1019	975	974	960	935	920	966	977	956	988	937	949	974	1002	1000	983	1005	
	2号炉		933	957	988	929	964	967	941	950	953	973	947	968	958	944	944	953	924	937	947	961	1001	924	965	23:49～1:17給じん停止
27	1号炉	1018	970	944	966	970	949	956	993	966	958	973	956	974	961	954	974	985	973	1013	986	999	1005	985	980	
	2号炉	965	947	969	941	932	944	968	949	853			990	941	922	947	946	961	913	973	941	977	962	947	941	8:31～11:44給じん停止
28	1号炉	977	953	929	925	990	968	971	942	965	959	964	925	942	982	988	970	955	1004	952	987	965	932	957	910	
	2号炉	939	954	951	955	958	976	973	959	965	945	965	969	961	982	960	941	973	953	979	918	974	961	991	925	
29	1号炉	954	940	980	959	973	982	992	973	997	1009	966	968	982	1020	918	955	945	969	940	950	918	961	972	982	
	2号炉	930	977	963	940	941	956	981	975	954	993	948	959	967	948	965	939	954	958	960	953	949	933	974	964	
30	1号炉	965	980	971	975	979	969	958	958	940	937	925	926	999	963	929	925	894	992	960	972	901	912	954	956	
	2号炉	933	957	965	918	969	958	964	937	961	993	954	961	964	979	981	954	936	936	933	938	936	915	893	906	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	998	955	933	953	947	984	956	953	906																定常運転～立下げ(8:58)
	2号炉	937	950	916	949	935	970	947	937	946	961	942	959	916	946	948	950	922	913	954	944	960	946	930	960	
2	1号炉																									休炉
	2号炉	957	938	925	958	925	942	955	926	933	954	961	939	925	930	926	915	932	938	939	936	937	921	954	945	
3	1号炉																									休炉
	2号炉	942	932	950	926	925	951	948	933	928	976	948	936	928	920	922	953	943	921	914	914	919	927	898	937	
4	1号炉																									休炉
	2号炉	903	914	915	925	914	930	937	912	924	928	921	924	934	898		943	903	910	905	907	916	914	917	902	13:58～15:45給じん停止
5	1号炉																									休炉
	2号炉	915	917	909	910	915	893	948	923	928	918	910	907	913	919	918	947	925	920	932	906	921	922	911	925	
6	1号炉																									休炉
	2号炉	926	907	922	905	937	920	928	917	917	947	950	906	925	922	916	935	935	934	928	933	951	918	909	903	
7	1号炉																									休炉
	2号炉	901	910	911	927	929	928	920	909	917	910	934	927	915	918	918	924	921	912		935	899	900	911	925	17:40～19:16給じん停止
8	1号炉																									休炉
	2号炉	919	913	928	848	916	927	918	924	924	926	921	933	915	883	889	970	909	908	901	908	901	913	923	906	
9	1号炉																									休炉
	2号炉	928	917	898	908	906	912	911	888	906	902	902	911	895	913	906	898	925	916	920	909	912	912	916	920	
10	1号炉																									休炉
	2号炉	908	889	911	905	897	887	910	893	900	818			1000	921	900	904	909	907	1009	994	995	999	985	1001	9:32～12:55給じん停止
11	1号炉																									休炉
	2号炉	986	987	989	1003	977	984	982	1002	986	1014	970	983	990	986	985	969	983	965	976	973	962	974	985	957	
12	1号炉																									休炉
	2号炉	990	963	992	984	977	967	827	785									918	1008	970	980	970	978	989	972	6:02～16:35給じん停止
13	1号炉																									休炉
	2号炉	967	957	961	977	986	974	997	973	970	959	962	961	963	977	979	965	968	959	973	953	972	974	953	959	
14	1号炉																									休炉
	2号炉	977	975	1007	960	961	952	982	918	898	962	955	954	936	936	941	943	964	965	975	974	977	970	979	984	
15	1号炉																									休炉
	2号炉	968	961	981	957	970	965	983	969	951	977	977	964	967	842	984	949	947	946	955	944	933	934	952	943	

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																									休炉
	2号炉	957	944	938	937	933	935	922	931	922	899	929	930	923	924	906	925	893	915	902	903	895	896	885	895	
17	1号炉																									休炉
	2号炉	903	892	919	904	907	899	918	903	926	893	911	891	884	902	893	907	901	905	866	897	885	897	883	885	
18	1号炉																									休炉
	2号炉	874	885	880	887	871	878	874	917	900	905	920	904	923	902	927	914	906	910	910	919	908	919	907	910	
19	1号炉																									休炉
	2号炉	902	859		913	904	908	898	901	919	904	875	933	910	921	892	928	929	927	907	909	918	908	904	893	1:38～3:01給じん停止
20	1号炉															924	870	905	1071	1004	1039		1012	994		立上げ～定常運転(15:40～) 20:49～22:11給じん停止
	2号炉	893	914	903	906	915	902	901	891	890	913	891	904	896	914	901	894	889	900	905	892	923	910	915	924	
21	1号炉	1071	921	1024	928	1002	935	984	1037	908	1004	938	952	875				853	917		914	989	1015	1043	1022	12:08～16:40給じん停止 17:34～19:12給じん停止
	2号炉	927	910	905		952	906	882	894	904	909	893	889	878	904	896	892	891	914	912	918	833	901	908	895	2:46～4:22給じん停止
22	1号炉	1053	1029	1022	1018	1058	1076	1069	1042	1059	1057	1011	1028	1007	1021	1031	1072	1065	1035	1061	1084	1050	1045	1041	1061	
	2号炉	912	909	913	901	901	912	908	908	856			971	920	917	916	931	909	917	920	912	916	915	923	916	8:43～11:40給じん停止
23	1号炉	1045	1048	1050	1027	1037	943	1010	1010	1057	1045	1060	913	939	1016	1056	1050	1059	1058	1048	1083	1110	1081	1083	1094	
	2号炉	917	938	928	920	927	916	921	944	919	920	913	941	920	924	928	919	926	938	922	927	928	929	924	921	
24	1号炉	1065	1057	1041	1047	1085	1145	1117	1094	1058	1046	1038	1009	948	1006	992	978	1036	1096	1068	1013	1003	1006	1010	1029	
	2号炉	926	922	930	955	930	996	978	979	989	1016	998	967	1002	1006	972	973	999	970		961	974	986	978	983	17:32～19:06給じん停止
25	1号炉	1026	1038	1057	1049	1032	1040	1030	1008	1013	1053	1038	1068	1025	1044	1017	1025	1016	1048	1095	1064	1041	1049	1092	1089	
	2号炉	999	999	997	976	985	995	1009	973	994	988	990	993	965	986	980	1001	988	1016	1008	1012	1009	1013	1023	1014	
26	1号炉	1076	1071	1062	1050	1038	1045	1061	1041	1067	1049	1052	1049	1067	1029	1050	1033	1027	1047	1044	1038	1045	1059	1119	1062	
	2号炉	992	1001	1007	990	1001	997	982	1005	1007	986	1022	994	987	993	999	1015	1024	995	988		1022	998	992	995	18:25～20:00給じん停止
27	1号炉	1060	1085	1111	1058	1032	1021	1043	1088	1086	1065	1051	1063	1052	1098	1039	1041	1040	1082	1027	1066	1075	1075	1073	1061	
	2号炉	984	997	987	989	1007	999	1011	1002	1002	1003	1009	996	1010	1004	1002	996	978	995	992	1015	1006	1002	1012	997	
28	1号炉	1102	1075	1096	1113	1102	1072	1027	1014	1000	1021	992	937	999	1060	959	1005	1069	1092	1130	1064	1028	11029	1024	1059	
	2号炉	996	1018	1000	1006	1009	1006	1009	1004	978				1015	990	991	988	991	977	998	992	987	1002	991	994	8:36～12:06給じん停止
29	1号炉	1089	1097	1080	1072	1078	1046	1029	1001	915					976	972	976	1042	1061	1050	1052	1050	1022	1038	1010	8:32～13:30給じん停止
	2号炉	988	990	992	975	982	990	976	977	983	967	980	981	970	977	965	991	972	991	986	978	981	985	1004	995	
30	1号炉	1064	1059	1048	1052	1083	1025	1034	1046	1061	1030	1043	1048	1058	1037	1068	1087	1071	1091	1060	1057	1097	1161	1134	1124	
	2号炉	983	985	966	987	991	980	976	970	974	966	962	968	958	978	981	978	980	974	991	978	981	972	982	977	
31	1号炉	1119	1107	1093	1119	1075	1069	1072	1024	1022	1059	1014	1016	1028	1023	1017	1002	1045	1048	1061	1026	1033	1057	1027	1046	
	2号炉	975	983	968	972	964	971	983	950	962	968	948	963	959	950	955	974	958	952	953	964	955	963	961	961	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位: °C)

8月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1036	1040	1035	1069	1044	1053	1028	1074	1087	1042	1050	1007	1007	1029	1079	1025	1042	1045	1055	981	1018	1082	1062	1049		
	2号炉	965	957	954		956	946	952	959	959	961	962	944	946	962	953	946	945	953	962	961	980	993	966	969	2:50～4:02給じん停止	
2	1号炉	1042	1066	1035	1014	1046	1046	1057	1073	1115	879	971	1038	1033	1004	1060	1085	1101	1064	1131	1084	1086	1081	1100	1042		
	2号炉	963	930	955	957	981	960	971	944	965	957	960	969	948	956	967	970	965	969	978	970	972	971	978	971		
3	1号炉	1010	1074	1042	1064	1070	1064	1080	1089	1094	1105	1081	1015	1029	1048	1063	1085	1079	1137	1087	1091	1098	1091	1151	1069		
	2号炉	977	976	964	976	968	958	983	966	969	958	958	959	961	957	967	946	965	968	972	968	960	962	962	961		
4	1号炉	1031	1046	1099	1083	1057	1132	1108	947	1070	1064	1099	990	1014	990	1001	989	1002	1055	1071	1058	1037	1037	1110	1090		
	2号炉	976	981	973	973	965	978	976	956																	定常運転～立下げ(7:45)	
5	1号炉	1101	1136	1113	1143	1072	1088	1152	1088	1120	1105	1107	1077	1115	1063	1066	1029	1045	1031	1159	1101	1068	1094	1033	1035		
	2号炉																									休炉	
6	1号炉	1065	1095	1053	1038	1034	1032	1057	1095	1067	756					977	1014	1004	1000	1002	979	1002	985	980	975	9:00～14:36給じん停止	
	2号炉																									休炉	
7	1号炉	962	980	1015	994	985	986	979	997	1007	1004	1011	989	980	986	990	990	978	992	997	983	999	1010	978	981		
	2号炉																									休炉	
8	1号炉	976	980	981	995	983	1005	983	991	993	998	982	1008	996	982	994	1007	1013	985	1005	997	989	988	970	963		
	2号炉																									休炉	
9	1号炉	991	979	989	1007	984	1025	1013	1009	994	979	955	963	976	979	980	980	966	992	972	983	987	988	1008	1006		
	2号炉																									休炉	
10	1号炉	1000	976	1016	1003	1065	1046	1054	1030	1011	991	991	995	1023	1024	1007	1007	1011	999	1024	1002	1002	1021	1010	1024		
	2号炉																									休炉	
11	1号炉	1030	1061	1064	1016	1019	1026	1016	1023	1024	1022	1014	963	967	989	969	997	995	1010	1019	1014	993	995	998	999		
	2号炉																									休炉	
12	1号炉	1003	1047	1017	1026	1008	1005	999	1024	1011	999	997	1019	976	983	980	1000	984	977	1010	1014	1026	1017	1014	1002		
	2号炉																									休炉	
13	1号炉	994	977	1003	996	993	1005	1002	996	930				981	995	1015	990	990	998	999	1001	1002	1008	1031	981	8:31～12:30給じん停止	
	2号炉																									休炉	
14	1号炉	1031	1022	1026	1019	1040	999	1016	986	993	923	896	933	978	1000	996	1009	1030	1018	987	959	978	997	974	976		
	2号炉																									休炉	
15	1号炉	977	961	969	994	995	997	964	981	964	976	966	990	975	980	976	962	1003	978	978	987	1001	974	996	994		
	2号炉																									休炉	

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	980	970	1007	1001	966	996	1009	1003	980	987	995	998	1001	985	996	954	986	996	1006	1017	969	990	1011	986	
	2号炉																									休炉
17	1号炉	1008	1027	1015	1006	1023	1033	1011	1017	1007	1014	1004	1000	981	994	1013	1000	962	1009	1026	1006	1038	1020	1027	1030	
	2号炉																									休炉
18	1号炉	983	1034	999	990	1000	1017	1035	1031	928					981	986	982	986	997	991	992	984	995	985	993	8:37～13:00給じん停止
	2号炉																									休炉
19	1号炉	1004	985	994	1002	975	987	981	986	978	979	977	990	991	980	991	989	990	996	984	968	992	982	996	990	
	2号炉																									休炉
20	1号炉	1001	983	972	963	976	976	995	988	987	980	960	969	996	1007	994	1015	1013	1010	997	1038	1017	999	1004	995	
	2号炉																									休炉
21	1号炉	1006	1020	1018	1012	1022	999	998	1025	1033	1041	1013	993	1011	974	944	989	1002	1010	962	988	984	993	980	986	
	2号炉																									休炉
22	1号炉	997	1022	1025	1010	959	1026	987	1005	1009	1014	1023	989	976	1037	1004	972	1001	993	977	1031	1002	1025	1038	1014	
	2号炉																									休炉
23	1号炉	1048	1027	1020	1036	1042	1057	1060	1075	1038	1033	1019	1022	1004	1000	1015	1022	1052	1011	1056	1059	1031	1040	1052	1041	
	2号炉																									休炉
24	1号炉	1027	1034	1040	1036	1029	1051	1057	1040	1023	992	1001	1019	1017	1031	1038	1019	1011	1021	1076	1059	1057	1056	1030	1042	
	2号炉																									休炉
25	1号炉	1023	1021	1010	1033	1036	1004	993	991	973											1010	1034	1006	1062	1044	8:39～19:20給じん停止
	2号炉																									休炉
26	1号炉	1021	1010	1017	988	1014	981	982	985	984	1002	967	983	993	1020	982	965	970	974	984	978	990	990	999	1000	
	2号炉																									休炉
27	1号炉	1006	967	984	974	993	977	966	983	964	994	986	969	943	896	886	972	982	976	978	974	987	1008	1011	1013	
	2号炉																									休炉
28	1号炉	979	1003	1010	986	977	987	977	989	995	965	988	1002	986	969	967	1029	1017	987	992	1013	1015	989	1031	1017	
	2号炉																									休炉
29	1号炉	1006	1018	975	993	1016	1022	965	991	979	993	984	992	991	984	974	971	982	988	994	1003	1000	989	996	994	
	2号炉																									休炉
30	1号炉	997	1022	1055	1035	1017	1037	1017	1017	1030	963	995	998	996	1011	997	1007	1024	1029	1010	1033	1013	999	989	990	
	2号炉									940	986	969	968	974	962	1015	982	974	948	954		932	1015	988	981	立上げ～定常運転(18:06～) 18:40～20:13給じん停止
31	1号炉	1023	1028	1030	1033	998	1014	982	977	1006	1008	1009	1020	998	982	1023	1016	1011	969	1030	1001	1003	1029	1015	1013	
	2号炉	952	962	990	991	995	1005	1012	998	977	978	979	995	991	989	974	980	972	976	962	985	992	986	992	988	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	951	999	1010	997	1000	1010	1008	1020	963			993	1011	982	957	978	1016	1036	961	1002	957	964	982	8:39～12:22給じん停止	
	2号炉	987	999	1017	974	977	977	984	982	971	968	972	964	982	995	958	940	959	974	939	949	952	919	946	944	
2	1号炉	1005	975	977	1003	978	995	1016	994	989	973	990	983	957	964	941	955	978	975	989	987	994	1017	979	957	
	2号炉	925	955	975	983	983	978	969	958	973	965	984	965	965	942	939	969	964	955	952	940	957	935	939	970	
3	1号炉	992	962	985	966	995	973	967	967	1000	995	990	974	990	1030	1048	1033	1004	1012	1002	1007	986	988	1010	992	
	2号炉	953	930	939	945	955	941	923	968	968	930	932	957	950	922	977	924	939	933	925	942	956	927	931	931	
4	1号炉	1000	985	1011	1003	1016	961	1011	978	994	1028	999	991	962	958	953	985	987	1010	1026	1007	1005	996	1017	1002	
	2号炉	924	914	914	922	935	940	931	936	928	952	941	925	956	938	942	925	938	971	993	1007	984	1007	997	992	
5	1号炉	1017	1000	989	1005	1011	995	1006	1006	1028	1002	1011	1019	1002	989	998	1009	1011	1019	1036	1025	1000	1007	1003	1035	
	2号炉	1019	987	980	968	976	965	962	959	1005	992	959	982	981	981	949	969	962	992	997	990	997	1009	1003	1015	
6	1号炉	1036	1020	1013	1020	1026	1029	995	1020	997	1019	1010	1010	1023	1004	1005	1021	1034	1028	1008	1040	1010	1053	1047	1055	
	2号炉	1020	999	991	990	989	1004	998	977	937	983	995	1022	1005	977	987	971	1006	996	993	975	974	982	1011	988	
7	1号炉	1055	1023	1021	978	990	1005	978	976	994	1008	1033	1027	1038	1006	1048	1049	1010	1004	989	994	1039	1085	1059	1079	
	2号炉	998	1008	996	1001	985	982	945	959	952	1005	994	1022	1001	953	924	977	981	990	1009	1003	992	994	1010	1015	
8	1号炉	1060	1044	1006	1040	1053	1028	1041	1048	1026	1038	1013	1011	942	954	1005	1005	982	1003	1039	1043	1014	1028	1044	1002	
	2号炉	1004	1012	993	954	967	955	962	959	894			1012	975	944	926	912	930	945	976	947	951	968	947	974	8:37～11:37給じん停止
9	1号炉	987	1007	958	954	1022	994	1033	1010	941				961	940	930	957	929	947	934	964	930	936	951	8:32～13:00給じん停止	
	2号炉	985	933	958	937	931	954	970	990	953	965	951	957	965	955	956	972	961	956	972	973	965	972	920	919	
10	1号炉	973	981	997	1015	993	983	963	949	932	957	962	941	952	939	928	947	942	951	970	951	958	946	984	959	
	2号炉	927	946	952	942	927	950	970	945	954	955	952	909	956	983	962	923	926	937	971	954	947	908	960	947	
11	1号炉	961	973	989	1049	1023	982	979	978	955	987	979	962	963	942	956	926	979	954	1002	987	978	968	965	944	
	2号炉	968	969	980	985	962	960	936	967	946	942	961	955	931	952	959	960	948	946	943	944	953	928	920	944	
12	1号炉	964	950	987	952	981	985	1016	978	1010	1024	973	967	946	951	1005	933	972	930	942	940	955	898	960	969	
	2号炉	981	924	956	939	948	924	922	956	962	962	958	925	954	938	908	949	953	958	965	961	949	956	943	916	
13	1号炉	940	945	943	946	960	954	966	1002	989	1043	976	1001	973	951	963	974	984	963	945	951	980	998	1004	978	
	2号炉	941	905	922	926	943	961	914	927	960	972	943	929	972	974	944	981	978	975	934	959	944	962	954	955	
14	1号炉	984	978	957	969	969	976	981	958	971	949	972	953	982	959	954	953	952	958	971	975	953	989	1034	949	
	2号炉	958	920	945	951	921	928	938	930	931	939	922	949	937	897	894	926	923	909	926	916	943	910	937	942	
15	1号炉	957	917	933	967	968	961	919	1010	944	968	921	906	886	892	896	900	902	907	971	932	982	996	1015	969	
	2号炉	934	921	918	938	939	936	918	921	952	973	948	940	896	923	933	986	943	953	943	943	933	927	931	935	

	9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1000	968	916	926	924	916	900	923	874																	定常運転～立下げ(8:43)
	2号炉	942	923	932	925	931	945	913	927	934	921	943	942	927	924	915	925	936	931	941	943	936	938	961	944		
17	1号炉																										休炉
	2号炉	949	936	932	922	916	946	924	937	943	946	938	943	947	933	928	922	928	762					941	907	1000	17:05～21:35給じん停止
18	1号炉																										休炉
	2号炉	975	969	995	961	970	969	973	960	957	960	964	1006	991	970	976	982	984	985	967	956	939	947	962	965		
19	1号炉																										休炉
	2号炉	979	988	992	989	987	977	949	973	972	972	964	975	967	957	962	941	937	974	978	988	986	990	997	1002		
20	1号炉																										休炉
	2号炉	990	956	975	978	954	965	974	956	996	983	978	969	959	1006	1003	983	996	965	1009	972	973	978	992	991		
21	1号炉																										休炉
	2号炉	971	942	935	946	1001	997	1002	998	1010	1007	990	998	962	973	992	979	978	955	985	986	956	957	985	977		
22	1号炉																										休炉
	2号炉	978	994	979	971	971	1008	975	995	997	967	960	958	985	998	991	973	996	980	954	987	983	977	993	996		
23	1号炉																										休炉
	2号炉	983	994	1006	995	988	1014	1001	1003	964	977	977	1025	992	932	997	1011	988	738	943	974	962	976	970	960		
24	1号炉																										休炉
	2号炉	936	971	976	951	984	966	953	952	978	995	982	925	926	927	934	939	935	996	955	936	948	1001	982	979		
25	1号炉																										休炉
	2号炉	975	1000	990	988	981	1021	981	969	962	955	985	976	951	959	955	961	982	946	967	950	945	957	934	974		
26	1号炉								878	950	924	937	886	887	883	901	872	868	946	995	996	1012	1004	1004	1006		立上げ～定常運転(7:33～)
	2号炉	979	971	952	965	963	962	956	938	966	962	988	986	976	971	942	967	972	974	961	939	970	945	969	972		
27	1号炉	1019	1012	1013	1010	999	992	1000	996	994	997	1013	992	995	974	1004	1003	1000	1016	1017	1012	981	1003	1015	1004		
	2号炉	986	951	970	958	946	952	973	983	962	961	970	965	960	962	964	970	949	954	972	943	957	958	940	964		
28	1号炉	990	1004	1009	1006	1005	1049	1018	998	1014	980	1002	1054	1033	1013	1113	1128	1120	1098	1063	1063	1094	1057	1044	1062		
	2号炉	954	972	963	965	966	966	944	948	976	951	961	982	972	956	963	977	985	960	975	933	965	991	980	998		
29	1号炉	1081	1103	1090	1079	1054	1073	1035	1079	1098	991	996	1012	1055	1051	1059	1053	1050	1043	1031	1074	1160	1099	1093	1084		
	2号炉	1003	969	973	980	971	948	969	937	973	962	965	957	963	972	950	949	928	963	949	965	969	964	967	949		
30	1号炉	1011	1069	1060	1059	1044	1065	1090	1074	1041	1068	1063	1057	1047	1032	1038	988	986	987	1022	1051	1063	1041	1066	1057		
	2号炉	959	945	956	960	951	942	927	941	867			991	928	960	945	950	923	946	939	997	953	938	952	983	8:31～11:53給じん停止	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

	10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉	1059	1048	1043	1034	1053	1075	1091	1089	1052	1022	1001	1028	1027	1014	1123	1099	1119	1104	1145	1072	1011	1066	1069	1099	
	2号炉	985	965	956	962	955	953	965	978	966	955	958	953	939	910	925	953	958	931	977	975	935	913	944	921	
2	1号炉	1065	1024	1045	972	1069	1066	1081	1090	1070	1074	1089	1067	1095	1072	7026	1050	1035	1053	1084	1074	1049	1038	965	1051	
	2号炉	963	938	1105	971	1019	1022	1007	995	1014	1025	1044	1046	1031	1051	978	1000	995	996	1030	1010	1043	1026	1012	982	
3	1号炉	1028	1041	1055	1054	1058	1023	1050	1038	1078	990	1022	1043	1057	1099	1110	1099	1097	1056	1080	1096	1063	1075	1064	1019	
	2号炉	1020	1033	985	983	973	1009	1006	995	1019	937	1003	991	991	977	987	971	996	971	981	990	978	994	971	981	
4	1号炉	1046	1011	1027	1051	1064	1030	1099	1103	1109	1105	1112	1113	1025	1042	1007	1044	1051	1078	1102	1110	1086	1095	1130	1137	
	2号炉	1002	999	979	984	973	981	971	981	957	977	968	959	900	972	961	979	953		939	963	956	936	949	913	16:13～18:05給じん停止
5	1号炉	1117	1118	1125	1106	1108	1066	1019	1068	1079	1070	1058	1050	1053	1089	1117	1087	1108	1144	1127	1123	1080	1127	1104	1079	
	2号炉	932	952	926	934	931	922	952	939	934	968	937	938	952	966	961	966	944	955	918	934	955	957	957	958	
6	1号炉	1055	1104	1059	1043	1013	1075	1087	1110	1042				1041	975	939	930	946	930	979	982	1002	997	990	995	8:34～12:44給じん停止
	2号炉	959	965	952	953	912	938	970	964	964	962	947	947	951	940	926	927	966	940	946	948	968	944	931	950	
7	1号炉	1006	1020	999	983	980	1000	983	1003	997	981	989	968	983	994	1003	1010	1006	1006	1040	1016	1027	1050	1043	1046	
	2号炉	961	929	952	933	948	957	938	943	842			945	937	931	940	934	933	942	938	941	929	959	955	954	8:32～11:01給じん停止
8	1号炉	1067	1066	1066	1037	1017	1024	1050	1062	1059	1073	1068	1054	1044	1021	1013	1004	1031	1043	1060	1031	1061	1055	1070	1079	
	2号炉	960	942	932	949	937	939	923	953	933	948	913	938	936	958	952	962	908	959	949	954	970	964	946	965	
9	1号炉	1088	1065	1062	1036	1056	1084	1032	1066	1081	1049	1006	1017	1065	1086	1086	1106	1072	1068	1075	1045	1043	1056	1082	1098	
	2号炉	958	927	970	936	953	975	957	945	938	985	980	981	942	932	924	917	921	946	922	927	925	905	924	952	
10	1号炉	1105	1099	1061	1038	1056	1042	1028	1056	1058	1058	1049	1040	1056	1035	1040	1057	1057	1048	1045	1077	1090	1044	1036	1066	
	2号炉	933	930	936	919	926	919	943	920	927	942	918	935	932	932	922	921	917	948	951	936	933	946	953	940	
11	1号炉	1077	1098	1084	1091	1091	1062	1095	1092	1067	1054	1070	1031	1046	1077	1108	1130	1112	1072	1047	1094	1120	1085	1080	1041	
	2号炉	944	944		925	948	937	936	945	958	942	913	916	922	950	964	951	945	963	969	954	938	943	919	913	1:58～3:04給じん停止
12	1号炉	1061	1096	1114	1103	983	1017	1046	1066	1062	1037	1067	1096	1109	1090	1102	1095	1080	1070	1092	1080	1110	1104	1025	1104	
	2号炉	932	930	961	952	962	953	989	953	946	935	935	948	919	933	961	931	936	938	943	927	937	962	943	914	
13	1号炉	1084	1071	1054	1040	989	1076	1106	1106	1113	1105	1078	1048	1003	1079	1074	1048	1080	1091	1097	1102	1115	1098	1089	1065	
	2号炉	919	950	967	914	946	952	941	942	954	860	942	940	930	906	937	930	914	945	948	929	937	919	954	943	
14	1号炉	1069	1046	1066	1062	1092	1028	1030	1038	1003			962	971	952	961	962	938	940	970	976	968	968	986	986	8:38～11:40給じん停止
	2号炉	925	914	953	924	934	957	948	952	925	965	931	938	914	939	935	939	936	916	947	920	926	934	923	949	
15	1号炉	965	963	986	936	956	951	1017	989	1002	1008	1004	992	976	970	1000	992	989	980	967	978	978	1003	1011	995	
	2号炉	933	922	911	938	918	932	934	930	929	935	939	953	936	921	938	917	918	926	931	924	945	934	857	982	

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1031	1024	1014	1024	1019	1014	1011	1000	1007	1002	942	953	978	958	981	991	966	1007	1099	1077	1051	1029	1043	1042	
	2号炉	918	893	931	932	942	930	938	925	848			963	898	903	896	902	910	914	940	921	918	927	934	929	8:35～11:38給じん停止
17	1号炉	1053	1065	1087	1090	1072	1044	1045	1022	1020	1082	1064	1050	1041	1028	1000	992	992	1030	1064	989	1053	1071	1058	1068	
	2号炉	932	960	964	930	948	945	934	924	945	922	898	934	947	921	938	908	953	945	945	932	959	934	946	978	
18	1号炉	1056	1091	1093	1076	1109	1102	1097	1114	1065	1099	1092	1103	1105	1082	1068	1016	990	1059	1064	1072	1094	1103	1101	1097	
	2号炉	933	941	938	925	923	924	929	913	916	950	935	904	933	922	927	948	916	920	917	950	943	916	922	940	
19	1号炉	1100	1120	1114	1100	1030	980	1010	1073	1045	1002	1041	1030	944	1047	1043	1038	1019	1029	988	951	962	965	1051	1069	
	2号炉	919	910	912	924	929	913	915	920	927	932	933	946	957	946	926	913	925	954	936	933	920	938	948	931	
20	1号炉	1066	1044	1044	1059	1062	1074	1080	1058	1048	1036	1003	1022	1065	1027	975	950	982	1006	999	959	993	942	967	943	
	2号炉	952	949	905	910	921	934	912	905	924	868	928	948	890	922	922	953	936	944	945	910	921	913	938	919	
21	1号炉	938	951	944	959	956	932	958	1069	983				1018	995	973	942	941	943	963	978	999	995	1081	1062	8:30～12:50給じん停止
	2号炉	926	967	931	921	914	921	900	929	912	911	744		921	898	926	947	928	911	916	914	909	928	964	935	10:13～12:22給じん停止
22	1号炉	1090	1081	1084	1083	1074	1068	1090	1034	1030	1038	986	1001	1016	1027	1079	1056	1072	1046	985	1025	1039	1053	1074	1069	
	2号炉	955	932	950	923	942	943	961	912	918	930	948	953	895	905	914	948	925	911	915	942	971	967	947	946	
23	1号炉	1077	1079	1079	1068	1054	1067	1036	1020	1030	1043	994	970	987	964	973	977	976	1012	1008	1028	1059	1053	1010	1005	
	2号炉	941	957	951	940	951	951	907	942	958	840	888	945	924	922	917	956	948	944	937	952	928	920		907	21:48～23:02給じん停止
24	1号炉	1030	1076	1072	1072	1091	1088	1083	1105	1122	1024	1041	1065	1025	1016	1018	1073	1022	981	1031	1048	1074	1092	1040	1045	
	2号炉	927	932	937	932	938	917	955	942	936	952	952	928	940	940	906	928	931	941	930	948	967	943	922	949	
25	1号炉	1044	1002	1056	1074	1116	1101	1044	1078	1040	1116	1070	1125	1110	1105	1101	1083	1083	1087	1043						18:35(停電)～24:10 給じん停止
	2号炉	975	917	950	942	951	945	964	969	946	955	923	928	913	918	923	936	942	930	873						18:35(停電)～給じん停止
26	1号炉	975	993	1032	1048	1052	1050	1037	988	960	956	997	902	940	950	947	1022	966	1012	1042	1023	1036	1030	1004	1037	
	2号炉				953	945	917	906	949	939	906	927	921	951	928	921	925	939	917	947	928	914	918	935	945	1:00～3:00給じん停止
27	1号炉	1026	1032	1035	1023	1051	1002	996	1007	1017	964	997	971	1019	1014	981	982	946	964	981	1015	1049	1049	1065	1073	
	2号炉	939	926	944	933	918	903	927	950	906	920	929	922	927	927	922	928	915	940	947	940	933	929	978	950	
28	1号炉	1078	1053	930	938	982	1007	1035	1035	1005				986	959	964	954	966	983	983	1022	1016	999	1025	1000	8:34～12:22給じん停止
	2号炉	969	935	935	952	909	944	956	950	955	952	937	931	967	923	932	956	952	956	934	948	917	922	932	937	
29	1号炉	1025	1052	1031	1010	1038	1053	1016	1015	987	988	991	1018	1003	969	994	959	972	1004	1053	1039	1004	935	1035	1075	
	2号炉	929	915	920	975	949	955	916	861	920	922	950	937	924	928	939	924	941	952	964	948	956	971	927	942	
30	1号炉	1068	1040	1047	992	1001	996	983	994	981	971	966	993	1037	1030	1027	1008	1033	1008	1049	1023	1060	1049	1032	993	
	2号炉	963	948	931	943	917	935	904	916	820			929	907	913	904	920	926	909	907	921	925	906	912	910	8:32～11:24給じん停止
31	1号炉	1015	1023	1014	1016	1013	1035	1034	1028	1035	1069	1052	1043	1022	1027	989	956	973	981	1022	1018	994	1008	1029	994	
	2号炉	910	917	921	906	906	906	913	923	933	916	905	928	943	939	898	899	911	909	930	926	923	937	913	916	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(单位: °C)

	1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉	992	1000	1010	991	1016	1066	1048	1008	991	995	988	1046	1035	1040	970	955	972	981	979	989	1027	1015	1019	1091	
	2号炉	907	914	925	906	925	899		936	901	924	925	935	927	912	908	905	916	916	908	914	917	914	916	934	5:45～7:04給じん停止
2	1号炉	1070	1055	1023	989	960	1024	1044	1038	1052	1049	1041	1032	1034	1023	1004	1026	1024	1037	1047	1047	1047	1053	1037	1041	
	2号炉	932	931	903	923	944	927	917	895	917	896	913	941	908	940	925	846	909	908	888	929	883	931	916	928	
3	1号炉	1039	1086	1071	1050	1024	995	970	955	967	964	960	973	1015	1012	969	962	933	951	963	1006	995	1020	1025	1026	
	2号炉	926	848	875	851	868	866	876	865	863	868	862	863	876	868	855	825	850	874	866	868	857	856	860	852	
4	1号炉	1016	979	1045	1067	1017	994	985	961	933				983	966	967	972	982	984	973	969	951	964	940	914	8:42～12:15給じん停止
	2号炉	906	923	925	918	904	902	911	908	909	896	936	944	909	906	908	927	910	910	902	900	914	903	937	909	
5	1号炉	993	988	1008	1027	1043	1020	961	971	967	992	1007	1028	1012	1006	999	1012	1015	1002	1007	997	1034	1021	996	995	
	2号炉	917	914	936	932	939	938	944	907	920	908	926	948	925	941	923	892	931	929	915	959	933	961	931	917	
6	1号炉	980	994	1005	974	997	988	1004	1005	1011	970	935	936	993	1023	1000	1013	1023	1027	1030	1021	1001	1029	1045	1037	
	2号炉	922	913	908	942	915	936	934	899	915			932	923	911	933	931	935	923	928	912	920	941	926	920	8:33～11:06給じん停止
7	1号炉	1042	1028	1012	1022	999	1029	987	1026	1012	1002	1057	1020	1048	991	971	984	984	1012	1034	1024	1026	1041	1092	1094	
	2号炉	933	923	917	932	948	915	910	913	916	942	943	926	886	876	909	922	925	915	930	924	922	918	958	901	
8	1号炉	1113	1066	1080	1064	1050	1089	1063	1066	1090	1058	1071	1065	1080	1069	1011	1074	1057	1066	1079	1066	1082	1051	1037	1057	
	2号炉	932	947	941	935	935	926	912	923	934	920	928	917	914	931	918	948	938	895	910	941	909	921	940	920	
9	1号炉	1042	1040	1060	1083	1061	1081	1067	1066	1048	1020	1002	1049	1074	1094	1091	1096	1090	1089	1100	1126	1099	1079	1108	1095	
	2号炉	908	915	917	914	923	910	913	927	939	906	892	923	927	929	915	926	903	906	957	929	936	932	937	916	
10	1号炉	1121	1119	1102	1096	1115	1095	1109	1067	1092	1091	1058	1097	1105	1100	1104	1100	1057	1061	1091	1076	1131	1094	1003	1035	
	2号炉	918	953	951	885	913	922	919	908	892	917	941	931	926	912	913	937	943	909	863	945	929	899	920	924	
11	1号炉	1056	1059	1091	1081	1096	1093	1090	1104	1012				1012	983	978	966	973	962	978	1006	1022	1014	1008	1003	8:35～12:10給じん停止
	2号炉	914	916	938	914	913	885	986	909	928	926	922	911	900	933	906	918	910	911	908	918	923	910	909	912	
12	1号炉	989	1024	1005	1004	1040	1063	1020	1018	993	963	994	1003	1033	1047	1034	1043	1040	1062	1039	1049	1032	1061	1033	1045	
	2号炉	927	926	943	890	914	900	912	924	852																定常運転～立下げ(8:47)
13	1号炉	1077	988	991	974	1020	1034	1030	1049	1042	1038	1035	1028	1004	947	955	966	959	943	997	1025	1045	983	1014	1043	
	2号炉																									休炉
14	1号炉	1031	1074	1045	1025	1002	975	992	991	1002	987	916	978	1030	1058	1060	1079	1079	1082	1093	1082	1045	1079	1040	1030	
	2号炉																									休炉
15	1号炉	1037	999	1043	1023	1064	1083	1105	1097	1100	1075	1083	1060	1051	1070	1083	1087	1098	1058	1061	1080	1078	1069	1083	1071	
	2号炉																									休炉

	11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1083	1075	1035	1012	1033	934	944	944	987	956	1010	1034	1058	1064	1067	1059	1052	1045	1026	1031	1046	1030	999	987		
	2号炉																										休炉
17	1号炉	1004	1037	1018	1002	1038	1022	1026	1003	1011	1021	1037	1018	1016	956	963	992	946	959	984	997	1003	975	964	989		
	2号炉																										休炉
18	1号炉	998	982	1012	979	979	1021	982	1008	1022	1018	994	962	1018	1002	1019	1029	955	989	1064	1085	1072	1088	1077	1096		
	2号炉																										休炉
19	1号炉	1085	1076	993	1061	1075	1111	1062	1012	1077	1054	1084	1102	1079	1116	1135	1099	1028	1031	999	1002	1040	1076	1043	995		
	2号炉																										休炉
20	1号炉	1013	991	882		870	1024	981	971	922																	2:43～4:45給じん停止 定常運転～立下げ(8:53)
	2号炉																										休炉
21	1号炉																										休炉
	2号炉																										休炉
22	1号炉																										休炉
	2号炉																										休炉
23	1号炉																										休炉
	2号炉																										休炉
24	1号炉																										休炉
	2号炉																										休炉
25	1号炉																										休炉
	2号炉																										休炉
26	1号炉																										休炉
	2号炉																										休炉
27	1号炉																										休炉
	2号炉																										休炉
28	1号炉																										休炉
	2号炉																										休炉
29	1号炉																										休炉
	2号炉																										休炉
30	1号炉																										休炉
	2号炉																										休炉

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

R7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位: °C)

	12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉																									休炉
	2号炉																									休炉
2	1号炉											753	937	965	969	985	974	979	980	996	973	993	990	992	987	立ち上げ～定常運転(10:39～)
	2号炉																									休炉
3	1号炉	985	992	1000	984	993	995	999	1025	1019	993	982	980	996	1002	994	1015	1042	1033	1029	1030	1043	1027	1054	1037	
	2号炉																									休炉
4	1号炉	1020	1010	1016	989	965	977	985	964	990	1003	1014	965	948	980	967	975	977	974	996	975	969	964	971	955	
	2号炉																									休炉
5	1号炉	961	979	978	978	986	979	985	969	981	966	976	990	1006	974	964	956	965	954	964	958	959	962	966	958	
	2号炉																									休炉
6	1号炉	958	979	982	962	1002	1009	1017	982	978	985	988	982	999	962	955	944	950	952	966	971	979	982	984	979	
	2号炉																									休炉
7	1号炉	986	971	973	978	991	991	994	1001	1005	985	978	967	983	973	984	985	979	991	979	988	979	984	985	983	
	2号炉																									休炉
8	1号炉	987	995	1019	1015	1003	1011	992	987	992	994	1001	982	964	980	964	953	961	965	959	946	954	968	963	958	
	2号炉																									休炉
9	1号炉	951	960	957	955	965	979	981	992	982	864			945	944	940	938	941	950	956	965	936	930	921	939	9:06～12:08給じん停止
	2号炉																									休炉
10	1号炉	948	932	946	922	922	929	923	929	930	939	944	940	924	944	971	947	941	949	952	956	957	929	930	929	
	2号炉																									休炉
11	1号炉	918	946	948	941	928	931	939	944	938	936	937	954	975	990	1085	1053	1032	1046	1035	1037	1031	1048	1084	1045	
	2号炉																									休炉
12	1号炉	1032	1039	1030	1005	982	994	1011	1023	1020	1005	1027	986	1000	986	985	994	1007	984	1009	1026	1017	1016	1009	1025	
	2号炉																									休炉
13	1号炉	1031	1017	1016	1017	1030	1011	1001	1014	979	990	982	1003	1016	1004	1012	1038	1049	1016	1014	1000	979	989	1003	994	
	2号炉																									休炉
14	1号炉	984	955	960	939	934	958	986	983	987	973	948	947	949	973	967	957	968	957	986	977	987	982	988	983	
	2号炉																									休炉
15	1号炉	975	972	961	963	962	965	965	970	954	944	984	1007	985	986	998	986	1003	971	943	937	934	925	933	938	
	2号炉																									休炉

燃燒室中の燃燒ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(单位: °C)

	12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉																									休炉
	2号炉																									休炉
2	1号炉											753	937	965	969	985	974	979	980	996	973	993	990	992	987	立ち上げ～定常運転 (10:39～)
	2号炉																									休炉
3	1号炉	985	992	1000	984	993	995	999	1025	1019	993	982	980	996	1002	994	1015	1042	1033	1029	1030	1043	1027	1054	1037	
	2号炉																									休炉
4	1号炉	1020	1010	1016	989	965	977	985	964	990	1003	1014	965	948	980	967	975	977	974	996	975	969	964	971	955	
	2号炉																									休炉
5	1号炉	961	979	978	978	986	979	985	969	981	966	976	990	1006	974	964	956	965	954	964	958	959	962	966	958	
	2号炉																									休炉
6	1号炉	958	979	982	962	1002	1009	1017	982	978	985	988	982	999	962	955	944	950	952	966	971	979	982	984	979	
	2号炉																									休炉
7	1号炉	986	971	973	978	991	991	994	1001	1005	985	978	967	983	973	984	985	979	991	979	988	979	984	985	983	
	2号炉																									休炉
8	1号炉	987	995	1019	1015	1003	1011	992	987	992	994	1001	982	964	980	964	953	961	965	959	946	954	968	963	958	
	2号炉																									休炉
9	1号炉	951	960	957	955	965	979	981	992	982	864			945	944	940	938	941	950	956	965	936	930	921	939	9:06～12:08給じん停止
	2号炉																									休炉
10	1号炉	948	932	946	922	922	929	923	929	930	939	944	940	924	944	971	947	941	949	952	956	957	929	930	929	
	2号炉																									休炉
11	1号炉	918	946	948	941	928	931	939	944	938	936	937	954	975	990	1085	1053	1032	1046	1035	1037	1031	1048	1084	1045	
	2号炉																									休炉
12	1号炉	1032	1039	1030	1005	982	994	1011	1023	1020	1005	1027	986	1000	986	985	994	1007	984	1009	1026	1017	1016	1009	1025	
	2号炉																									休炉
13	1号炉	1031	1017	1016	1017	1030	1011	1001	1014	979	990	982	1003	1016	1004	1012	1038	1049	1016	1014	1000	979	989	1003	994	
	2号炉																									休炉
14	1号炉	984	955	960	939	934	958	986	983	987	973	948	947	949	973	967	957	968	957	986	977	987	982	988	983	
	2号炉																									休炉
15	1号炉	975	972	961	963	962	965	965	970	954	944	984	1007	985	986	998	986	1003	971	943	937	934	925	933	938	
	2号炉																									休炉

	12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	933	944	958	973	948	923	924	920	901				924	912	930	931	907	913	903	901	903	904	892	901	8:33～12:20給じん停止	
	2号炉																									休炉	
17	1号炉	901	901	902	910	914	913	927	918	912	909	913	903	907	909	974	1023	972	989	1015	1022	1038	1044	1040	1021		
	2号炉																									休炉	
18	1号炉	1032	1012	1034	1023	1014	1038	1041	1021	1029	1024	1021	1004	1012	1005	990	1007	1003	1011	1015	1018	1001	1013	1000	1001		
	2号炉																									休炉	
19	1号炉	996	998	1008	1022	1009	1002	1011	1026	1004	988	1017	987	985	1005	978	1010	1007	1005	1005	983	988	1018	1041	1042		
	2号炉																									休炉	
20	1号炉	1031	989	985	982	995	978	983	942	973	994	989	976	991	979	974	982	998	981	986	1001	994	1014	1004	998		
	2号炉																									休炉	
21	1号炉	994	991	1020	991	994	1002	1001	993	997	1000	983	999	1013	1033	1026	1002	1018	1005	1006	978	991	961	968	973		
	2号炉																									休炉	
22	1号炉	1000	964	966	989	995	970	973	988	971	982	996	988	989	978	968	982	968	981	1023	1034	997	956	967	1001		
	2号炉																									休炉	
23	1号炉	982	964	969	986	978	971	984	958	899			973	959	975	946	965	961	952	970	962	963	946	969	946	8:32～11:46給じん停止	
	2号炉																									休炉	
24	1号炉	953	951	968	967	968	994	1002	950	964	947	950	959	965	955	957	955	953	962	936	963	975	982	984	979		
	2号炉																									休炉	
25	1号炉	978	941	950	948	943	961	989	971	973	948	955	925	963	936	942	980	936	956	944	951	943	943	939	930		
	2号炉																									休炉	
26	1号炉	934	956	960	949	949	943	952	940	952	948	936	951	974	942	958	981	978	955	988	977	955	952	951	955		
	2号炉																									休炉	
27	1号炉	950	963	1004	984	963	980	987	988	979	961	947	933	904	926	910	918	921	950	938	926	939	945	947	940		
	2号炉																									休炉	
28	1号炉	951	981	993	1000	990	978	957	973	983	973	982	987	976	972	956	958	969	952	960	981	995	989	985	1000		
	2号炉																									休炉	
29	1号炉	949	957	981	1008	1009	1010	1015	1023	1014	956	953	956	955	945	946	943	939	976	1002	996	1018		990	1030	20:53～22:00給じん停止	
	2号炉																									休炉	
30	1号炉	973	1032	1032	1055	1072	1095	1111	1099	1101	1065	1038	1018	1021	1054	1031	1034	1044	910							17:07～24:00給じん停止	
	2号炉																									休炉	
31	1号炉			1012	1025	1050	1020	1006	996	995	999	1004	1000	1006	1003	1009	1009	1045	1041	1049	1059	1031	1045	1035	1035	0:00～17:07給じん停止	
	2号炉																									休炉	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位: °C)

	1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1043	992	987	978	954	957	986	1026	1046	951	971	983	982	974	988	974	993	995	1017	1021	1025	1048	1035	1032		
	2号炉																										休炉
2	1号炉	1038	1051	1045	1031	1047	1041	1040	1048	1030	1034	1028	1025	1006	976	1013	1012	1013	1034	1009	983	973	973	1006	1024		
	2号炉																										休炉
3	1号炉	1026	1023	1039	1017	1016	1006	1004	1000	996	1010	1018	1019	1023	1041	1043	1038	1030	1038	1009	1012	1012	1018	1013	1012		
	2号炉																										休炉
4	1号炉	1015	996	993	1009	992	977	985	995	977	1012	1010	1005	984	994	1008	1026	1024	1041	1053	1044	1033	1041	1052	1055		
	2号炉																										休炉
5	1号炉	1052	1029	1021	1027	1016	1019	1043	1053	1025	1065	1024	1068	1064	1061	1057	1058	1055	1046	1032	1025	1047	1044	1003	1055		
	2号炉																										休炉
6	1号炉	1062	1035	1037	1013	1017	1027	1048	1038	1018					1002	988	959	1005	991	996	995	977	963	977	982	7:06～13:18給じん停止	
	2号炉																										休炉
7	1号炉	987	987	990	982	1044	1027	1011	996	1016	1027	1035	1016	1016	1027	1054	1062	1039	1048	1042	1014	1031	1031	1031	1031		
	2号炉																										休炉
8	1号炉	1026	1013	1011	1036	1025	1009	1042	1012	1048	1049	1026	1031	1021	992	1015	994	1029	1015	1040	1034	1034	1009	1011	997		
	2号炉																										休炉
9	1号炉	1003	1014	1015	1021	1028	1010	1069	1047	1057	1055	1042	1056	1084	1059	1072	1054	1041	1064	1050	1044	1043	1020	1036	1036		
	2号炉																										休炉
10	1号炉	1042	1037	1033	1048	1044	1023	1052	1049	1038	1054	1044	1055	1034	1056	1044	1043	1070	1041	1053	1048	1072	1076	1060	1094		
	2号炉																										休炉
11	1号炉	1071	1034	1050	1029	998	1023	1041	1056	1020	949	996	1021	1043	1049	1045	1046	1030	1061	1060	1052	1056	1057	1057	1062		
	2号炉																										休炉
12	1号炉	1064	1055	1044	1068	1063	1077	1045	1059	1060	1005			989	1050	1057	1084	1086	1072	991	1039	1072	1074	1073	1070	9:20～12:25給じん停止	
	2号炉																										休炉
13	1号炉	1089	1083	1090	1067	1063	1060	991	983	984	954															定常運転～立下げ(9:11)	
	2号炉																										休炉
14	1号炉																										休炉
	2号炉																										休炉
15	1号炉																										休炉
	2号炉																										休炉

1月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																										休炉
	2号炉																										休炉
17	1号炉																										休炉
	2号炉																										休炉
18	1号炉																										休炉
	2号炉																										休炉
19	1号炉																										休炉
	2号炉																										休炉
20	1号炉																										休炉
	2号炉																										休炉
21	1号炉																										休炉
	2号炉																										休炉
22	1号炉																										休炉
	2号炉																										休炉
23	1号炉																										休炉
	2号炉																										休炉
24	1号炉																										休炉
	2号炉																										休炉
25	1号炉																		968	987	1085	1085	1026	987	989	～定常運転(16:53～)	
	2号炉																										休炉
26	1号炉	983	960	966	965	990	964	977	979	986	982	970	961	969	972	966	977	944	956	988	1006	1013	981	994	947	23:29～24:00給じん停止	
	2号炉																										休炉
27	1号炉							934	794			962	970	1006	1012	989	998	973	988	1004	1010	1006	1039	993	1016	0:00～6:22給じん停止 7:17～10:32給じん停止	
	2号炉																										休炉
28	1号炉	979	980	973	975	984	968	989	991	980	989	990	992	1009	1015	989	1005	1009	1016	1020	1013	1012	1008	1004	996		
	2号炉																										休炉
29	1号炉	991	996	977	988	989	984	995	983	1022	1031	1006	998	1027	999	996	994	995	988	987	989	998	999	1008	1011		
	2号炉																										休炉
30	1号炉	1002	1015	1025	1070	1047	1028	1016	1006	998	990	980	993	991	982	1015	1023	1048	1043	1036	1037	1045	1041	1044	1036		
	2号炉																										休炉
31	1号炉	1024	1020	1004	1028	1041	1016	1004	1006	1000	988	987	994	997	1002	1024	1006	1038	983	975	996	1006	1023	1017	983		
	2号炉																										休炉

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位: °C)

[illegible]

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位: °C)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1110	1095	1105	1033	1076	1082	1086	1108	1064				1104	1050	1024	1034	1027	1064	1055	1032	1038	1034	1043	1033	8:37～12:27給じん停止
	2号炉																									休炉
17	1号炉	1039	1036	1049	1037	1031	1033	1047	1068	1071	1051	1054	1055	1046	1045	1075	1086	1050	1052	1066	1056	1056	1064	1058	1066	
	2号炉																									休炉
18	1号炉	1053	1071	1099	1103	1125	1140	1149	1149	1097	1069	1089	1074	1144	1104	1119	1105	1099	1093	1091	1124	1104	1101	1090	1104	
	2号炉																									休炉
19	1号炉	1076	1111	1112	1131	1077	1066	1106	1083	1079	1069	1069	1098	1067	1027	1075	1062	1075	1075	1062	1068	1061	1036	1061	1055	
	2号炉																									休炉
20	1号炉	1059	1028	1028	1088	1078	1076	1084	1060	1082	1150	1057	1081	1061	1050	1070	1085	1079	1076	1080	1078	1091	1078	1089	1085	
	2号炉																									休炉
21	1号炉	1094	1101	1107	1087	1083	1067	1080	1063	1070	1048	1083	1069	1071	1061	1073	1063	1057	1075	1094	1037	1063	1051	1080	1098	
	2号炉																									休炉
22	1号炉	1098	1110	1094	1079	1085	1066	1046	1048	1070	1051	1015	1043	1019	1031	1050	1046	1018	1096	1094	1053	1047	1042	1050	1069	
	2号炉																									休炉
23	1号炉	1054	1080	1066	1090	1089	1092	1070	1061	1062	1036	1019	978	997	979	989	978	992	1024	1040	1015	1038	1040	1016	1032	
	2号炉																									休炉
24	1号炉	1072	1056	1074	1051	1045	1081	1055	1068	1065	1079	1049	1010	1035	1041	1071	1059	1094	873					1025	1076	17:07～22:15給じん停止
	2号炉																									休炉
25	1号炉	1065	1031	1041	1047	1046	1034	1037	1050	1042	1036	1040	1070	1040	1044	1042	1045	1020	1022	1035	1075	1025	1049	1036	1036	
	2号炉																									休炉
26	1号炉	1036	1056	1054	1046	1055	1056	1065	1047	1069	1056	1045	1014	1044	1053	1061	1057	1051	1055	1044	1033	1039	1038	1039	1043	
	2号炉																									休炉
27	1号炉	1055	1029	1017	1020	1035	1026	1030	1034	1037	1045	1026	1051	1047	1045	1037	1042	1032	1064	1045	1028	1037	1035	1043	1030	
	2号炉																									休炉
28	1号炉	1036	1036	974	906	1018	1038	1033	1043	1048	1046	1068	1049	1071	1088	1094	1086	1080	1079	1074	1084	1065	1083	1087	1062	
	2号炉																									休炉

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

	3月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉	1067	1033	1059	1063	1072	1080	1107	1107	1130	1088	1030	1013	1022	1026	1022	1017	1049	1080	1069	1096	1093	1090	1086	1103	
	2号炉																									
2	1号炉	1109	1116	1131	1147	1112	1115	1122	1111	1120	1111	1123	1128	1117	1134	1089	1103	1146	1086	1076	1133	1099	1086	1085	1087	
	2号炉														793	882	857	902	937	986	949	942	950	987	989	立上げ～定常運転(13:15)
3	1号炉	1099	1105	1135	1102	1131	1109	1096	1085	1049					1049	1028	1022	1046	1007	1054	1018	1035	1026	998	1047	8:34～13:08給じん停止
	2号炉	995	998	1002	996	1027	1010	1010	1023	997	973	974	961	949	935	936	945	950	958	955	963	963	953	965	957	
4	1号炉	1036	1041	1039	1035	1028	1059	1052	1039	1031	1070	1084	1099	1077	1101	1061	1071	1079	1077	1062	1042	1059	1052	1070	1053	
	2号炉	965	984	998	981	961	988	977	999	966	995	1005	1029	980	981	932	963	987	992	992	982	952	958	961	947	
5	1号炉	1061	1074	1073	1083	1083	1066	1040	1053	1047	1105	1120	1123	1115	1108	1066	1063	1093	1058	1110	1079	1070	1066	1081	1071	
	2号炉	947	999	1027	1031	1041	1009	1012	1013	974	971	977	991	985	1020	1022	988	992	993	994	1008	992	1018	1017	988	
6	1号炉	1074	1063	1078	1073	1067	1091	1087	1047	1058	1087	1066	1067	1118	1117	1097	1094	1090	1081	1087	1101	1085	1074	1087	1075	
	2号炉	1016	1018	1016	1017	991	1008	998	1005	1005	1015	975	978	1001	961	969	969	1017	1029	998	960	974	1001	1013	1027	
7	1号炉	1079	1097	1095	1070	1073	1079	1095	1087	1071	1103	1072	1061	1070	1093	1072	1074	1062	1069	1089	1096	1092	1071	1079	1101	
	2号炉	1029	969	949	987	964	973	984	990	974	983	995	975	980	966	957	982	962	949	959	956	957	1003	993	992	
8	1号炉	1108	1094	1080	1092	1085	1047	1064	1062	1055																定常運転～立下げ(8:45)
	2号炉	985	918	981	981	1006	961	953	947	945	988	1003	998	978	982	956	945	951	968	951	951	941	938	934	938	
9	1号炉																									休炉
	2号炉	985	918	981	981	1006	961	953	947	945	988	1003	998	978	982	956	945	951	968	951	951	941	938	934	938	
10	1号炉																									休炉
	2号炉	936	950	943	935	932	950	940	944	953	957	959	951	972	950	946	933	939	950	951	950	942	950	948	946	
11	1号炉																									休炉
	2号炉	956	945	933	947	959	940	944	953	949	935	920	930	931	944	941	962	940	743				941	936	921	17:02～21:21給じん停止
12	1号炉																									休炉
	2号炉	906	922	949	960	965	959	964	967	956	970	946	925	930	949	941	974	988	971	953	931	924	917	943	947	
13	1号炉																									休炉
	2号炉	914	952	967	928	933	960	967	972	972	949	950	948	958	959	965	954	960	961	970	966	960	939	954	949	
14	1号炉																									休炉
	2号炉	956	946	925	938	956	974	964	962	966	969	964	969	988	995	995	927	963	967	952	987	962	976	985	996	
15	1号炉																									休炉
	2号炉	961	977	1000	1001	979	995	989	966	980	986	963	974	984	985	984	982	985	975	976	976	953	967	977	957	

3月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																									休炉
	2号炉	983	980	957	931	950	939	955	946	960	977	965	969	942	980	971	986	981	955	965	960	937	932	966	943	
17	1号炉																									休炉
	2号炉	926	914	937	940	934	939	978	945	969	962	953	973	985	1007	1002	985	985	981	963	935	945	970	995	985	
18	1号炉											990	1015	1063	1032	1051	1060	1058	1046	1033	1045	1046	1031	1029	1035	9:46～定常運転
	2号炉	1005	969	925	940	954	953	954	957	916						989	982	998	1000	996	971	1011	996	1000	995	8:35～14:01給じん停止
19	1号炉	1019	1018	1025	1017	1026	1021	1037	1051	1045	1064	1068	1050	1066	1039	1072	1065	1051	1027	1008	1007	1022	1029	1010	983	
	2号炉	986	972	970	984	971	991	987	986	997	944	976	972	991	984	1009	988	977	991	981	953	970	981	960	950	
20	1号炉	984	978	992	996	1003	988	983	984	1006	998	989	994	1005	1012	1010	997	984	988	992	1009	1003	1030	1002	1011	
	2号炉	921	917	915	919	911	899	901	907	913	921	942	946	954	929	991	944	951	939	943	955	960	965	968	973	
21	1号炉	1005	1031	1022	1019	1057	1007	992	985	1015	989	997	1000	991	1043	1012	1018	1052	1023	1023	1005	1055	1045	1086	1056	
	2号炉	961	961	975	964	980	984	971	957	954	943	968	955	954	940	916	932	932	947	969	956	988	981	973	934	
22	1号炉	1118	1072	1054	1053	1054	1067	1066	1098	1068	1055	1027	995	1051	1041	1033	1066	1051	1026	1037	1036	1066	1086	1086	1100	
	2号炉	923	947	975	973	983	949	946	956	970	958	954	955	938	941	964	983	980	990	979	985	953	967	985	987	
23	1号炉	1084	1084	1050	1093	1079	1089	1100	1072	1089	1094	1111	1089	1101	1090	1103	1093	1069	1021	1014	1050	1013	1018	1021	1026	
	2号炉	968	950	919	955	973	989	971	988	989	967	1001	1004	998	979	983	984	981	970	957	958	962	976		958	21:01～23:21給じん停止
24	1号炉	1034	1080	1085	1028	1066	1070	1039	1066	1033	1065	1074	1069	1084	1099	1099	1043	1087	1070	1031	1038	1039	1035	1083	1083	
	2号炉	947	947	991	965	945	962	962	961	996	998	962	971	979	989	990	991	991	961	962	964	961	973	989	964	
25	1号炉	1092	1069	1049	1035	1012	1002	1001	1018	1018	1067	1079	1089	1092	1090	1105	1095	1077	1028	1038	1014	1005	1043	1032	1019	
	2号炉	996	1004	992	990	987	976	948	995	917				993	959	997	987	947	941	953	942	963	945	962	951	8:32～12:33給じん停止
26	1号炉	1048	1030	1071	1060	1064	1133	1137	1168	1093					1089	1072	1049	1059	1037	1027	1037	1033	1061	1088	1086	8:31～13:19給じん停止
	2号炉	923	945	967	967	946	943	941	929	933	926	903	947	989	970	1003	966	948	978	954	937	974	1001	1012	1005	
27	1号炉	1067	1054	1049	1048	1062	1072	1064	1040	1049	1053	1078	1076	1072	1083	1063	1084	1062	1066	1068	1117	1112	1052	1080	1069	
	2号炉	991	971	993	982	949	970	994	976	980	899	894	953	955	972	982	958	961	956	953	988	994	951	927	952	
28	1号炉	1064	1074	1071	1093	1087	1068	1065	1083	1074	1071	1064	1017	1029	1054	1022	1008	1037	1063	1115	1125	1124	1111	1095	1100	
	2号炉	980	949	933	955	945	959	977	990	945	968	969	974	988	989	991	971	963	968	961	924	911	965	990	1008	
29	1号炉	1121	1086	1074	1034	1038	1039	1053	1038	1051	1057	1069	1057	1063	1058	1075	1074	1061	1069	1075	1070	1072	1070	1101	1091	
	2号炉	1014	966	961	963	967	963	967	954	926	965	977	969	967	946	941	925	926	913	920	925	937	972	969	991	
30	1号炉	1103	1116	1105	1093	1075	1083	1070	1103	1067	1101	1095	1084	1101	1094	1096	1117	1126	1095	1059	1084	1064	1081	1118	1108	
	2号炉	975	975	969	967	979	957	982	960	979	993	996	976	954	975	978	984	941	975	972	994	993	981	987	947	
31	1号炉	1088	1083	1073	1091	1092	1072	1096	1053	1088	1107	1090	1057	1050	1090	1087	1089	1096	1101	1083	1095	1115	1089	1077	1097	
	2号炉	941	942	949	967	983	980	939	941	989	1003	995	984	985	970	950	961	1000	1007	986	981	959	975	988	975	