

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1090	1086	1070	1126	1082	1100	1120	1105	1116	1102	1113	1117	1105	1087	1097	1109	1103	1106	1088	1113	1089	1059	1058	1085	8:32～13:37給じん停止
	2号炉	967	972	976	966	973	975	993	974	896					1022	1001	1017	984	997	975	1006	1016	988	978	978	
2	1号炉	1091	1085	1145	1150	1133	1082	1060	1046	1014					1080	1048	1042	1006	1051	1012	1014	1038	1031	1067	1029	8:30～13:00給じん停止
	2号炉	1005	980	957	986	1002	979	995	990	983	986	973	988	1001	1003	978	965	954	968	971	965	966	966	955	983	
3	1号炉	1038	1057	1097	1093	1096	1075	1084	1089	1097	1065	1091	1078	1058	1083	1054	1080	1057	1061	1052	1027	1019	1032	1070	1040	
	2号炉	990	997	998	948	964	1003	1023	1035	996	1002	984	1002	990	977	974	996	979	976	958	988	985	976	969	950	
4	1号炉	1077	1048	1025	1077	1050	1062	1043	1080	1100	1038	1011	988	991	1000	1020	1040	1066	1073	1040	1068	1057	1080	1088	1076	
	2号炉	968	982	984	996	984	963	956	953	957	977	984	998	996	987	997	942	965	918	978	973	969	968	989	976	
5	1号炉	1104	1080	1075	1092	1103	1102	1086	1085	1078	1056	1025	1012	1016	1025	1064	1040	1073	1094	1071	1065	1099	1113	1108	1086	
	2号炉	970	976	983	993	988	981	989	1006	1011	988	938	964	963	1008	1012	1001	995	984	1018	1004	981	990	1003	979	
6	1号炉	1082	1084	1081	1074	1067	1086	1110	1110	1093	1112	1100	1100	1074	1073	1074	1095	1094	1101	1140	1093	1110	1077	1071	1123	
	2号炉	979	971	1009	999	1003	990	972	967	993	1009	1006	997	988	982	978	995	992	982	990	983	1023	991	1043	1023	
7	1号炉	1106	1109	1103	1074	1084	1103	986	1018	1050	1084	1057	1067	1067	1078	1060	1076	1069	1071	1080	1084	1083	1067	1067	1062	
	2号炉	968	999	987	990	961	933	936	963	979	1006	1015	1008	997	989	976	964	973	982	973	980	981	959	977	977	
8	1号炉	1067	1009	994	1031	1045	1027	1024	1007	1016	1015	1039	1044	1023	1063	1057	1092	1082	1061	1073	1102	1111	1109	1109	1116	8:31～12:11給じん停止
	2号炉	977	948	963	970	956	934	1000	980	900				1002	944	967	941	921	926	947	982	977	1014	971	942	
9	1号炉	1084	1064	1061	1044	1057	1072	1060	1070	1012				1067	1030	997	984	989	995	1002	1045	1067	1049	1037	1024	8:30～12:17給じん停止
	2号炉	910	949	965	989	964	969	960	939	942	963	998	939	956	986	981	967	927	940	967	993	989	959	980	917	
10	1号炉	1014	1014	1034	1012	1029	1012	1034	1020	1009	1048	1042	1066	1043	1008	1026	1031	1027	1030	1047	1061	1062	1035	1042	1040	
	2号炉	930	923	956	953	960	971	967	970	960	984	978	958	980	960	944	954	939	970	971	952	977	931	961	930	
11	1号炉	1048	1048	1052	1056	1031	1047	1065	1059	1061	1042	1053	1005	1010	1007	1025	1015	1033	1044	1064	1073	1064	1062	1078	1073	
	2号炉	967	960	932	967	970	952	970	952	935	933	960	964	962	956	959	925	940	940	969	956	954	971	1007	1004	
12	1号炉	1060	1073	1089	1084	1067	1073	1048	1049	1064	1035	1031	1023	1007	982	1015	1047	1048	1072	1052	1050	1069	1069	1051	1031	
	2号炉	950	956	938	933	976	993	987	942	935	959	951	945	948	978	990	987	985	993	972	973	956	960	937	901	
13	1号炉	1030	1045	1045	1049	1075	1079	1079	1091	1054				1076	1056	1021	992	1012	1032	1014	1030	1050	1037	1043	1026	8:32～12:50給じん停止
	2号炉	917	929	995	999	983	1015	1021	1009	985	971	995	1026	990	967	976	994	969	994	966	974	973	984	983	986	
14	1号炉	1034	1042	1022	1011	1018	1010	1034	1049	1024	1002	996	995	1008	1018	1010	1000	993	1000	1009	1023	999	1001	998	1008	22:05～24:04給じん停止
	2号炉	960	1002	971	961	976	998	1007	1010	951	954	956	968	953	976	978	947	951	953	950	976	959	938	958		
15	1号炉	1021	1027	1039	1035	1026	1031	1045	1024	1029	1037	1031	1040	1048	1054	1021	1007	1013	1026	1037	1032	1035	1023	1027	1032	
	2号炉	929	972	976	973	945	980	1004	969	974	962	935	937	983	968	953	960	942	962	959	953	987	973	956	924	

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1026	1031	1022	1018	1038	1049	1044	1027	1032	1041	1057	1061	1059	1033	1010	1006	991	999	995	1022	1009	1005	1006	1022	
	2号炉	925	974	974	962	973	987	973	967	959																定常運転～立ち下げ(8:32～)
17	1号炉	1020	1030	1027	1020	1023	1013	1021	1014	1015	1005	1016	1018	1012	1003	1005	1043	1042	1036	1037	1025	1022	1025	1039	1057	
	2号炉																									休炉
18	1号炉	1030	1031	1024	1019	1024	1026	1019	999	999	1019	1002	1004	1011	1019	1021	1045	1033	1031	1023	1033	1019	1022	1027	1001	
	2号炉																									休炉
19	1号炉	989	1006	1023	1032	1017	1018	1005	1018	1037	1028	1005	1001	980	962	979	1018	1038	1025	1028	1050	1027	1041	1025	1020	
	2号炉																									休炉
20	1号炉	1041	1021	1001	1005	1018	1018	1000	989	1002	987	973	978	985	970	961	1001	986	896				1040	963	951	17:03～21:45給じん停止
	2号炉																									休炉
21	1号炉	944	951	958	951	950	963	975	982	986	981	972	962	950	957	946	952	961	962	971	972	968	965	968	967	
	2号炉																									休炉
22	1号炉	979	977	994	980	973	974	979	987	985	985	1007	1013	1016	1017	1011	1017	1012	1018	1015	1013	1013	1005	1003	997	
	2号炉																									休炉
23	1号炉	1007	1012	998	1026	1022	1019	1008	1016	1012	1038	1030	1038	1004	978	974	993	1008	1026	1005	1008	1004	996	1006	990	
	2号炉																									休炉
24	1号炉	1015	993	992	1007	1024	1032	1034	1016	1027	1019	1003	1004	992	989	989	980	991	982	975	991	994	1007	1005	1013	
	2号炉																									休炉
25	1号炉	1021	1010	993	996	989	985	976	974	976	965	931	929	931	928	946	946	958	972	958	947	969	954	974	989	
	2号炉																									休炉
26	1号炉	992	993	998	994	997	991	999	1009	1003	999	974	977	958	950	953	943	953	989	1017	1008	986	986	1008	1004	
	2号炉																									休炉
27	1号炉	1019	998	1009	1008	1009	1038	1025	1011	991	1004	1005	1015	1025	1034	998	988	1011	1025	1012	1011	1021	1020	1015	1023	
	2号炉					923	919	919	926	928	932	924	916	934	914	978	948	936	958	973	949	979	977	994	1005	
28	1号炉	998	1005	1012	1023	1000	988	1027	1002	978	848	913	954	986	974	968	988	976	975	977	968	990	1011	996	1035	
	2号炉	978	987	1033	1016	998	989	992	999	998	969	953	955	943	963	966	955	967	978	989	996	1029	1034	1031	1030	
29	1号炉	1008	1017	1010	992	989	987	986	968	973	968	965	957	955	947	950	943	954	961	964	970	999	1004	989	990	
	2号炉	1005	1044	1013	969	992	953	966	936	970	971	991	1004	1011	998	958	940	941	950							17:26～給じん停止
30	1号炉	1008	995	992	983	981	984	998	996	995	1014	1001	1004	978	976	959	960	980	975	977	993	1000	1033	1016	969	
	2号炉											950	1006	934	910	904	924	951	960	982	988	989	994	967	941	～12:08給じん開始

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	950	1008	1009	1003	994	995	998	1022	1000	1037	1036	1030	1007	1016	1026	1031	1021	1019	1021	1021	1031	1000	1015	996	
	2号炉	962	943	959	942	937	914	956	953	940	972	979	990	974	1010	988	1012	1028	987	974	982	990	1009	1021	979	
2	1号炉	997	1029	1027	1040	1031	1063	1058	1027	1036	1022	1003	988	957	975	973	976	992	1015	1037	1012	997	1027	1012	1029	
	2号炉	970	1002	995	968	980	1015	1009	1045	1023	1004	1000	987	1002	1009	956	949	960	977	970	989	1027	1001	1018	1012	
3	1号炉	1022	1040	1037	1031	1022	1033	1024	1029	1037	1012	978	963	970	981	963	953	973	995	1016	1013	1021	1039	1029	1036	
	2号炉	994	994	1016	993	980	987	971	1002	999	993	982	1002	996	1000	968	986	980	994	1012	1005	999	996	987	976	
4	1号炉	1030	1026	1025	1020	1030	1031	1028	1036	1044	1035	1027	1020	1014	1003	986	962	959	1012	1031	1002	945	975	1057	1055	
	2号炉	979	998	1014	968	974	982	957	997	1024	994	1014	990	962	934	989	988	992	995	1004	1006	989	940	970	973	
5	1号炉	1075	1052	1024	1009	1036	1064	1083	1053	1029	966	943	956	962	954	937	936									定常運転～立下げ(17:00)
	2号炉	949	1022	1029	1038	1046	1049	994	983	1001	978	968	970	993	996	954	1011	975	979	972	980	980	967	965	950	
6	1号炉																									休炉
	2号炉	960	979	993	993	996	1028	1028	1002	996	1010	995	962	952	955	971	961	981	969	969	982	960	955	977	987	
7	1号炉																									休炉
	2号炉	987	980	978	972	972	979	985	964	934	795	1008	1046	1049	950	975	976	988	992	970	979	985	1027	1041	1026	8:41～12:47給じん停止
8	1号炉																									休炉
	2号炉	1022	1030	1012	1001	994	1003	998	994	965	977	973	966	998	969	960	945	974	966	969	951	988	970	972	951	
9	1号炉																									休炉
	2号炉	968	964	982	964	971	963	959	997	1007	979	979	997	992	988	994	954	963	1003	1023	1031	1013	1022	1008	1022	
10	1号炉																									休炉
	2号炉	1015	1004	997	998	997	984	977	964	997	976	962	965	978	989	1005	991	979	946		993	989	983	987	981	17:29～19:22給じん停止
11	1号炉																									休炉
	2号炉	960	953	980	982	977	983	975	967	988	976	996	996	944	957	993	1021	1021	1018	1002	1021	1013	1014	989	1008	
12	1号炉																									休炉
	2号炉	994	980	996	994	976	970	980	999	1004	1005	995	979	970	973	963	969	967	996	1008	1001	983	1008	1002	948	
13	1号炉																									休炉
	2号炉	962	993	1008	1025	1026	1034	1047	1023	1040	1028	945	938	939	966	962	979	954	999		1018	974	1003	990	997	17:44～19:20給じん停止
14	1号炉																									休炉
	2号炉	990	1027	1002	1000	1019	1024	1031	1001	926			1052	966	973	958	973	965	984	983	975	989	999	976	992	8:33～11:50給じん停止
15	1号炉																									休炉
	2号炉	1000	989	999	1009	1011	1024	1033	1029	1003	964	976	961	983	985	1003	977	920	993	976	973	980	1009	1020	983	

	5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉																									休炉
	2号炉	968	965	987	985	1006	1005	985	996	1020	1013	1023	1035	1030	1005	1017	1000	988	998	1005	1028	1004	997	1007	996	
17	1号炉																									休炉
	2号炉	984	1022	1024	1021	1039	1031	1014	1007	1001	1032	1016	1002	1055	1064	1031	1035	1052	1009	1010	987	967	1016	1002	1015	
18	1号炉																									休炉
	2号炉	984	1004	1008	987	1013	1052	1051	1042	1026	952	985	972	977	952	946	967	1018	1045	1038	10028	1030	1048	1051	1031	
19	1号炉																									休炉
	2号炉	1038	1042	1022	1021	980	993	1018	1023	1013	1014	1024	983	997	1009	1013	1010	984	977	1030	992	1007	1029	1009	1041	
20	1号炉																									休炉
	2号炉	1042	1001		996	968	968	958	978	1024	1018	1028	1014	990	956	955	941	965	1036	1065	1075	1064	1019	1027	1012	1:52～3:02給じん停止
21	1号炉											981	988	975	962	930	937	968	965	969	960	953	965	973	972	～10:14→定常運転
	2号炉	992	1035	1012	992	985	991	1023	1009	998	1020	1002	1013	1000	986	986	1020	1003	972	932	991	1034	1028	1024	1006	
22	1号炉	976	996	990	890	826		835	863																	3:03～6:32給じん停止 定常運転～7:41立下げ
	2号炉	960	977	1020	1033	1001	1020	987	941	1005	974	1036	906	890	961	971	962	1015	996	1027	1027	1023	991	1036	1007	
23	1号炉																									休炉
	2号炉	1007	992	1003	1012	1015	962	984	971	998	974	986	1006	990	1026	1021	1014	991	978	1005	1005	1024	1009	1015	1012	
24	1号炉																									休炉
	2号炉	1022	1047	950	950	981	1049	1037	1063	1029	1023	1018	1024	1013	977	1006	1008	1013	1025	1038	1024	1031	1033	997	1041	
25	1号炉																									休炉
	2号炉	1014	1010	995	984	934	964	984	1027	1022	1055	1004	927	971	968	979	1003	984	1014	1032	1013	1015	1000	993	995	
26	1号炉								841	899	942	927	935	918	915	915	939	938	951	926	938	934	937	968	948	～立上げ(7:46)→定常運転
	2号炉	1019	1032	1002	990	983	1026	958	969	917					1065	936	970	957	959	989	977	1006	989	1018	998	8:33～13:42給じん停止
27	1号炉	950	958	949	945	962	962	951	939	938	944	945	962	970	902	905	924	932	931	957	958	954	994	977	983	
	2号炉	996	1005	1008	996	1015	1031	1018	999	1016	1004	960	966	971	1000	939	967	1002	987	1010	1005	1043	1048	1000	1039	
28	1号炉	980	973	969	967	937	931	951	937	953	950	938	947	949	929	897	930	950	956	947	944	913	933	961	955	
	2号炉	992	1040	1037	1027	1004	988	1010	1012	961	947	987	982	977	949	981	985	1020	963	972	972	947	969	951	1016	
29	1号炉	964	964	949	940	941	958	927	924	936	962	947	935	935	922	922	956	933	926	948	945	943	954	952	947	
	2号炉	966	981	1016	989	1011	1006	987	983	995	973	976	1001	993	969	949	956	960	976	983	1001	999	1017	1006	1011	
30	1号炉	940	949	948	943	943	948	941	933	965	943	956	940	947	941	943	942	948	950	1043	1021	1019	1021	1022	1032	
	2号炉	940	949	948	943	943	948	941	933	935		956	940	947	941	943	942	948	950	1043	1021	1019	1021	1022	1032	8:58～10:30給じん停止
31	1号炉	1006	1024	1024	1018	1014	1015	1006	989	1013	990	1000	1008	997	933	989	1002	974	984	973	985	1012	1003	973	950	
	2号炉	982	994	1018	1005	978	976	1006	1024	996	995	997	980	1001	988	949	965	957	1000	1001	1015	963	968	949	1017	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和8年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(單位: °C)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	963	950	942	932	967	961	945	970	943	926	936	928	947	947	932	909	918	916	919	933	927	944	922	927	
	2号炉	998	1004	983	996	1007	995	1002	992	984	976	966	949	964	4006	994	995	927	951	1002	1024	975	1025	961	999	
2	1号炉	908	911	899	919	922	942	946	920	876				934	902	905	904	922	911	921	922	911	912	902	931	8:31～12:04給じん停止
	2号炉	984	951	965	950	1002	997	981	959	992	971	954	963	939	946	952	982	939	977	1002	981	987	963	990	992	
3	1号炉	917	915	919	906	927	944	999	1027	1011	961	941	925	948	972	932	952	978	966	956	968	963	952	967	967	
	2号炉	974	967	956	966	988	977	969	945	982	1009	974	962	1003	1006	970	966	970	954	955	965	941	1028	951	975	20:40～22:01給じん停止
4	1号炉	956	968	957	963	948	951	962	970	957	933	946	947	930	941	915	933	949	937	949	934	931	925	934	926	
	2号炉	985	978	968	958	970	1005	988	905																	定常運転～立下げ(8:41)
5	1号炉	920	916	951	927	962	943	907	951	946	945	941	929	937	949	920	941	931	901	880	916	907	914	924	918	
	2号炉																									休炉
6	1号炉	916	932	923	906	897	929	910	909	910	908	895	903	899	915	959	912	911	920	895	997	1015	1018	1018	1022	
	2号炉																									休炉
7	1号炉	1014	1016	1035	1043	1029	1017	1025	1013	1003	973	936	969	991	1002	992	1000	995	971	1006	992	972	980	974	980	
	2号炉																									休炉
8	1号炉	986	999	1000	969	969	990	995	994	996	973	989	983	966	985	980	973	988	991	1002	993	1010	993	1016	996	
	2号炉																									休炉
9	1号炉	989	958	965	980	962	961	972	953	886				996	968	983	989	970	972	997	999	999	973	984	985	8:32～12:23給じん停止
	2号炉																									休炉
10	1号炉	966	992	1008	986	988	1006	996	1012	1025	1019	988	1004	1031	1020	1039	999	1021	1013	1042	1040	1016	1019	1013	1032	
	2号炉																									休炉
11	1号炉	1020	992	1019	999	996	1008	1008	1013	1010	988	992	1025	995	951	935	973	996	974	1010	982	976	993	984	976	
	2号炉																									休炉
12	1号炉	977	1001	970	968	968	960	944	977	971	950	982	996	985	1002	993	991	972	998	998	1010	1007	980	1006	979	
	2号炉																									休炉
13	1号炉	979	1006	1017	1011	1000	1010	1001	1006	992	1014	997	989	974	999	998	1008	1006	989	1010	1019	987	979	996	987	
	2号炉																									休炉
14	1号炉	973	967	1009	985	967	977	998	985	968	943	975	988	954	956	974	956	971	964	953	962	966	943	947	938	
	2号炉																									休炉
15	1号炉	941	935	954	955	939	943	940	950	924	933	933	940	923	893	917	939	948	948	959	957	953	961	938	971	
	2号炉																									休炉

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	947	956	980	974	980	975	969	982	910	704	922	1014	964	1005	970	953	954	948	971	990	966	962	961	988	
	2号炉																									休炉
17	1号炉	984	972	979	981	970	979	979	977	981	959	961	980	954	961	987	952	996	952	970	971	975	974	973	964	
	2号炉																									休炉
18	1号炉	969	967	976	975	977	956	953	973	968	952	965	960	968	952	968	965	964	966	986	949	973	971	992	981	
	2号炉																									休炉
19	1号炉	993	976	965	968	958	959	969	976	961	960	968	961	962	981	967	949	960	949	969	972	968	971	981	968	
	2号炉																									休炉
20	1号炉	977	954	958	952	963	964	970	965	965	970	965	961	956	956	964	961	966	967	984	952	963	955	947	974	
	2号炉																									休炉
21	1号炉	971	946	955	960	975	966	955	965	945	950	937	941	954	951	949	955	951	946	9959	972	947	952	966	972	
	2号炉																									休炉
22	1号炉	958	958	988	963	948	947	964	964	976	951	964	972	976	966	935	965	981	979	974	983	981	1000	991	987	
	2号炉																									休炉
23	1号炉	983	984	972	976	974	968	980	982	906				1045	963	968	958	963	968	961	963	962	972	979	973	8:32～12:11給じん停止
	2号炉																									休炉
24	1号炉	973	957	962	959	981	970	969	977	956	966	950	962	971	963	956	979	957	963	976	996	984	1026	1001	994	
	2号炉																									休炉
25	1号炉	978	964	977	967	978	979	973	1001	965	964	954	954	959	943	952	960	948	952	951	935	943	971	947	958	
	2号炉																									休炉
26	1号炉	949	947	963	951	965	962	970	968	971	950	963	948	932	939	933	942	940	947	945	938	949	943	949	947	
	2号炉																									休炉
27	1号炉	958	954	961	948	963	938	945	950	955	943	969	933	953	959	954	943	934	938	938	986	952	941	937	932	
	2号炉																		953	967	969	956	958	939	967	～16:13立上げ→定常運転
28	1号炉	933	935	952	938	952	951	940	920	916	909	938	951	946	951	938	936	908	911	906	927	925	926	906	911	
	2号炉	958	970	954	964	959	939	960	988	981	986	997	1001	959	993	1001	1022	1023	1008	988	1003	987	988	973	983	
29	1号炉	905	912	904	906	919	917	905	917	922	908	911	928	906	893	892	912	947	934	959	964	954	936	963	959	
	2号炉	974	981	995	1007	1004	1009	985	969	1009	956	962	944	946	941	951	944	988	981	1011	1023	989	975	1007	994	
30	1号炉	947	948	940	937	923	952	940	942	927				1010	907	923	905	909	919	922	916	922	926	947	926	8:47～12:29給じん停止
	2号炉	995	1007	1012	1008	1004	973	958	974	994	955	997	1019	941	933	970	932	939	960	948	940	983	947	949	945	